

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001**

No FC/DF3/M-2011/2965

Dated 11-11-2011

**FIRE SAFETY CERTIFICATE**

Certified that the New Krishna Public School, Prakash Vihar, Karawal Nagar Delhi, Comprised of ground & First floor with 17 rooms have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education GNCTD and verified by the officer concerned of this department on 24-10-2011 in the presence of the Principal, and that the building is fit for occupancy, class B "Educational Building" with effect from 11-11-2011 for a period of three year, subject to conditions printed overleaf.

Issued on 11-11-2011 at New Delhi.



Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Principal  
New Krishna Public School Prakash Vihar,  
Karawal Nagar Delhi.
2. The Director Education,  
Government of N.C.T Delhi,  
Old Sectt, Delhi 110054



#### Condition

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. The clarification with regards to electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc. may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularization of unauthorized construction, unauthorized use of land, if any.
6. The owner/occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name & address of the building : New Krishna Public School, Pankash Vihar
2. Type of Occupancy : Educational Kazal Ngr. Delhi
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. NA Dated: \_\_\_\_\_
5. Fire Safety directives letter No : NA
6. Date of inspection : 24.10.11
7. Name of the Inspecting Officers : Gurmitk Singh
8. Name and designation of officers  
from the building side : Manager
9. Year of Construction : 1995
10. Applicant's letter No. : NKPS/324/2011 dt 28.9.11

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	4.5 mtr.	4.5 mtr.	MR
	• Width of internal road	NA	NA	
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2 Nos.	2 Nos.	MR
	• Basements	NA	NA	
	b. Width of staircases			
	• Upper Floors	1.45 & 1.06 mtr.	1.45 & 1.06 mtr.	MR
	• Basements	NA	NA	
	c. Protection of exits			
	• Fire check door	NA	NA	
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	1.0 mtr wide	1.0 mtr. wide	MR

3	<b>Compartmentation.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	/	/	
4	<b>Smoke Management System.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	NA	
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	2 Nos. ABC & CO <sub>2</sub> ISI marked	10 Nos. ✓ ABC & CO <sub>2</sub> YES	MR MR "
6	<b>First-Aid Hose Reels.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm	/	
7	<b>Automatic fire detection and alarming system.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	/	/	
8	<b>MOEFA</b>	NA	NA	
9	<b>Public Address System.</b>	NA	NA	
10	<b>Automatic Sprinkler System.</b>	NA	NA	
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	/	/	

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	/	/	
15	Exit Signage.	NA	NA	
16	Provision of Lifts.	NA	NA	
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	/	/	
17	Standby power supply	NA	NA	
18	Refuge Area.	NA	NA	
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	/	/	
19	Fire Control Room	NA	NA	
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	/	/	
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	

The fire protection systems provided in the building were test checked and found functional at the of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire : required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~ .....

Signature of the Inspecting Officer

Name

Designation

*Govind*  
*27/10/11*

Signature of the Inspecting Officer

Name *Govindk Singh*

Designation *ADD (LH)*