

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/School/2011/ 3012

Dated: 16/11/11

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Kanya Vidyalaya**, located at **Ghitorni, New Delhi-110030** Comprised of **Single Storey Building** owned / occupied by **MCD** The inspection of school was carried out & found complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire/Safety/ 2011/3298 to 3398 dated 01/03/11 issued by Directorate of Education, Govt. of NCT of Delhi and verified by the officer concerned of Fire Service on **17/10/11** in the presence of **Mrs S.Bhalls** and that the building / premises is fit for occupancy class **Group 'B' Education Building Sub Division B- I** with effect from **08/11/11** for a period of Three years subject to condition as mentioned below.

Issued on 16/11/11 at New Delhi by.


Chief Fire Officer
Delhi Fire Service

Copy to: - (1) The Principal,
Sarvodaya Kanya Vidyalaya,
Ghitorni, New Delhi-110030
(2) Director of Education,
Old Secretariat, Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protections measures shall be maintained in perfect conditions all the time as seen during inspection.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be the risk and responsibility of thr management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010.the form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Sarvodaya Kanya Vidyalaya, Ghitorni, New Delhi.
2. Type of occupancy:- Education Building Schools Up to Sr. Sec. Level
3. Type of case:- New Case
4. Details of previous NOC:- No
5. Fire safety directives No.- No
6. Date of inspection:- 17/10/11
7. Name of the inspecting officer:- ADO S.S. Kaushik
8. Name & designation of officer
From the building side:- Mrs. S. Bhalls Principal
9. Year of construction:- 1994
10. Applicant's letter No:- 700 dated 22/07/11

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Fire Requirement <i>as per E.P. Giradia 17/10/11</i>	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Approachable	Yes	MR
	2) Gate width	<i>Required</i>	<i>provided</i>	<i>MR</i>
	3) Width of internal road	<i>MR</i>	—	—
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases	No staircase	Not Required	Not Required
	1. Upper floors			
	2. Basements			
	B. Width of staircase			
	1. Upper floors			
	2. Basements			
	C. Protection of exits			
	1. Fire check door			
	2. Pressurization			
	D. No. of continuous staircase to terrace			
	E. Width of corridor		Openspace	
	F. Door size	<i>Required</i>	<i>one min provided</i>	<i>MR</i>
3.	Compartmentation		Not Required	
	1) Fire check door			

	2) Sealing of electrical shafts		Not Required	
	3) Fire rating of shaft door		/	/
	4) Water curtain		/	/
	5) Fire Dampers		/	/
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Not Required	/
	2) Upper floors	12 a/c per hour	/	/
5.	Fire Extinguishers			
	1) Total numbers	Required ISI Marked	18 Nos. 5 K.G.	MR
	2) Types		ABC	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel		Not Required	
	1) Total number of each floor		/	/
	2) Length of hose reel hose	30 m	/	/
	3) Nozzle diameter	5 mm	/	/
7.	Automatic Fire Detection & Alarming System		Not Required	
	1) Type of detectors		/	/
	2) Location of main panel	/	/	/
	3) Location of repeater panel	/	/	/
	4) Alternate source of power	/	/	/
	5) Hooter's Location	/	/	/
8.	MOEFA	/	Not Required	/
9.	Public Address System	Electric bell provided	provided	MR
10.	Automatic Sprinkler System		Not Required	
	1) Basement	/	/	/
	2) Upper floors	/	/	/
	3) Sprinkler above false ceiling	/	/	/
11.	Internal Hydrants		Not Required	
	1) Size of riser/down-comer	/	/	/
	2) Number of hydrants per floor	/	/	/
	3) Hose box	/	/	/
12.	Yard Hydrants	Not Required		

7/13

	1) Total number of hydrants			
	2) Hose box			

13.	Pumping Arrangement	Not Required		
	1) Ground level			
	a) Discharge of main pump			
	b) Head of main pump			
	c) Number of main pump			
	d) Jockey pump out put			
	e) Jockey pump head			
	f) Stand by pump output			
	g) Stand by pump head			
	h) Auto starting/Manual stopping			
	2) Terrace level			
	a) Discharge of pump			
	b) Head of pump			
	c) Power supply			
	d) Auto starting of pump			
14.	Captive Water Storage for Fire Fighting	Not Required		
	1) Under ground tank capacity			
	a) Draw-off connection			
	b) Fire service inlet			
	c) Access to tank			
	d) Over head tank capacity			
15.	Exit Signage.	Not Required		
16.	Provision of Lifts.	Not Required		
	a) Pressurization of lift shaft			
	b) Pressurization of lift lobby			

	c) Communication in lift car	1	1	1
	d) Fireman's switch			

	e) Lift signage	—	—	—
17.	Stand by Power Supply	Not Required		
18.	Refuge Area	Not Required	Open space area	—
	Total area location			
19.	Fire Control Room	Not Required		
	a) Detector system panel	1	1	1
	b) Flow switch panel			
	c) PA system panel			
	d) Battery backup			
	e) Building floor plan	1	1	1
20.	Special Fire Protection System for Protection of special Risk, if any:			Not Required

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010 ~~issue as noted at serial numbers~~ -----

Accordingly DFA is put up for

Signature of the inspecting officer

Naushil
24/10/24
Signature of the inspecting officer

Name

S-S. Raushik
Name

Designation

Asstt. Div. Officer
Designation