

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001

No: F6/D FS/MS/school/2011/2889

Dated: 04/11/11

To

The Principal,
Shahid Captain Amit Verma Govt. Co-Ed Sarvodaya Vidyalaya,
C-Block Inder puri,
New Delhi-110012.

Ref No : No.2284/SCAV/11 dated 14.09.2011.

FIRE SAFETY CERTIFICATE

Certified that the – Shahid Captain Amit Verma Govt Co-Ed Sarvodaya Vidyalaya C-Block, Inder puri, New Delhi-110012 comprised of - ground floor plus one upper floors, owned/occupied by Govt.of N.C.T. school has complied with the fire prevention and fire safety requirements in accordance with the Director of Education circular No. F.16/Estate/CC/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 18.10.2011 in the presence of - Sh. K.L. Meena Vice .Principal and that the building/premises is fit for occupancy class – group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on04/11/11.....at New Delhi.



Copy to:

1. The Director
Govt. of N.C.T. of Delhi
Directorate of Education,
Old Secretariat, Delhi

Chief Fire Officer
Delhi Fire Service



INSPECTION REPORT

1. Name & address of the building : Shahid Captain Anil Verma Govt Co-ed Sarvodaya Vidyalaya
 2. Type of Occupancy : Educational C Block, Under P.O. No.
 3. Type of Case : New Case/ Renewal
 4. Details of previous NOC : Letter No. NIL Dated: _____
 5. Fire Safety directives letter No : NIL
 6. Date of inspection : 13/10/2011
 7. Name of the Inspecting Officers : Dr. H.L. Anje
 8. Name and designation of officers from the building side : Dr. H.L. Meena, Vice Principal
 9. Year of Construction : _____
 10. Applicant's letter No. : 2284/SCA/11 dt. 14.9.11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R.	9 mtr	MR
	• Gate width	R	01 Mtr.	MR
	• Width of internal road	NR	ND	NMR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	2 Nos	MR
	• Upper Floors	R	—	—
	• Basements	NIL	NIL	NIL
	b. Width of staircases	R	144 & 147 cms	MR
	• Upper Floors	—	—	—
	• Basements	NIL	NIL	NIL
	c. Protection of exits			
	• Fire check door	MR	MR	NMR
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	2 Nos	MR
	g. Width of Corridor	R	1.2 Mtr	MR
	h. Door Size	R	100 x 205 cms	

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NR	NP	NMR
		/	/	/
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N.R	N.P	NMR
		30 a/c per hour	/	/
		12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	R	Privatized	NR
		ISI marked	ABC type	
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NR	NP	NMR
		30 m	/	/
		5 mm		
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NR	NP	NMR
		/	/	/
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	NIC	NIC	NIC

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	—	—	—
11	Internal Hydrants	NIR	ND	NMR
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	/	/	/
12	Yard Hydrants.	NIR	NIP	NMR
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	/	/	/
13	Pumping Arrangements.	NIR	NIP	NMR
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14	Captive Water Storage for fire fighting.	NIR	NIP	NMR
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	/	/	/

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15	Exit Signage.	NR	NP	NMR
16	Provision of Lifts.	—	—	—
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
17	Standby power supply	NR	NP	NMR
18	Refuge Area.	NR	N.P.	N.MR.
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
19	Fire Control Room	NR	N.P.	N.MR
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	/	/	/
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR	NP	NMR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers:.....NIL.....

H. L. Anuja

Signature of the Inspecting Officer

Name H. L. ANEJA.

Designation Div. Officer.

Signature of the Inspecting Officer

Name

Designation

