

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001**

No F6/DFS/MS/EH/2011/1023

Dated 30/05/11

**FIRE SAFETY CERTIFICATE**

Certified that the V Spot Restt. (A Unit of Leisure Steak Hospitality Pvt. Ltd.) in Shop No 2, at ground floor of Salcon Rasvilas bldg., Plot No D-1, Saket District Centre New Delhi. The bldg. comprises of three tier basement, Ground & five upper floors. The premises was inspected by the officers concerned of this department on 18-5-2011 in the presence of Site Engineer and found that the said Restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy with effect from 30-5-2011 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed overleaf.

Issued on 30/05/2011 at New Delhi.



Chief Fire Officer  
Delhi Fire Service

Copy to :-

1. M/S. V Spot (A Unit of Leisure Steak Hospitality Pvt. Ltd.)

Shop No 2, Salcon Rasvilas Plot No D-1,

Saket District Centre New Delhi.

2. Dy. Health Officer

MCD South Zone

Green Park New Delhi.

Ref: Letter No 1556/DHO/52 dated 25/2/11

Letter No.

with ref. above quoted letter, premises have been ~~visited~~ inspected by DO (BCP) & ADOLNP in the presence of Site Engineer on 24/5/11

During inspection, it was observed that the Prop. intends to run Restt. at ground floor, Shop No. 2 of the bldg known as Saloon Rasvilas at D-1, Distt. Centre Saket. The bldg. comprises 3 basements, ground & five floors. The said bldg. have already been issued NOC from fire safety point of view by this deptt. vide letter no. 86/ms/085/2009/324 dated 03.02.09 The bldg. is accessible to fire engines and the proposed restaurant at ground floor have two exits also.

Fire protection measures as seen during inspection on the bases of 10 points is mentioned below.

1. Access — Available.
2. No. width Type of Exits — Already available in bldg. & restt. is at Gr. fl. only.
3. Protection of Exits by FCD — Already provided in bldg.
4. Compartmentation — Already provided in bldg.
5. Smoke management — Provided
6. Fire extinguishers — Provided. water Co<sub>2</sub> & Co<sub>2</sub> & ABC Type.
7. First Aid Hose Reel — Already provided.
8. Automatic fire detection & — Provided in whole bldg.
9. MOEFA — Provided
10. P.A. System — Already provided in bldg.

- |  |   |                           |
|--|---|---------------------------|
| 12. Intermal hydrant & yard hyd.       | — | Provided in bldg.         |
| 13. Pumping arrangements               | — | Already existing in bldg. |
| 14. Captive water storage              | — | Already provided in bldg. |
| 15. Exit Signages                      | — | Provided.                 |
| 16. Provision of Lifts.                | — | Already provided in bldg. |
| 17. Stand by power supply              | — | Existing in the bldg.     |
| 18. Refuge Area                        | — | Provided in bldg.         |
| 19. Fire control room                  | — | Not required.             |
| 20. Spl. fire protection for spl. risk | — | Not required.             |

The aforesaid fire fighting arrangements were checked and found functional during inspection. Hence the said restaurant is considered safe from fire safety point of view and accordingly the fire safety certificate is put up for perusal & sign. if approved.

Submitted please.

W. S. S. S.  
24/5/11



1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7 - The management shall declare every year in form 'J' prescribed under Delhi fire Service Act, 2007 & Rule-2010, that Fire prevention and Fire safety measures are in best repairs.