

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

NO: F.6/DFS/MS/2011/1818

DATED; 02/08/11)

To

The Principal
Govt. Co. Education Sr. Sec. School,
Sector-2, Rohini,
Delhi- 110085

Sub: Regarding issuance of NOC from fire safety point of view in r/o
Sarvodaya Kanya Vidhyalaya, Karala, Delhi- 110041.

Sir,

Kindly refer to your letter No. 1436 dated 02/12/2010 on the subject cited above. In this connection the premises was visited by officer of this department and observed that the premises is having **Ground floor only** (first floor is under construction) is built on **plot area** of approx **27051 square meter** and the **covered area** of the school is **3412.94 sq. meter.** There are **2233 students in 36 class rooms.** **Only 12 rooms** are having double doors.

The fire safety arrangements such as fire extinguishers sand and water buckets, Conduit wiring MCB etc have been provided. The systems were checked and found functional at the time of inspection.

The premise is **not meeting** the requirement for the class room as specified in the Director of Education circular No. F.16/Estate/CC/Fure Safety/2011/3298-3398 dated 01/03/2011. i.e. Two exits for each class room.

In view of the above NOC from fire and safety point of view cannot be considered at this stage.

Yours faithfully,



Chief Fire Officer,
Delhi Fire Service

Copy to:

Director of Education
Old Sectt.
Delhi