

NO. F6/DFS/MS/2011/1865

Dated: 05/08/2011

FIRE SAFETY CERTIFICATE

Certified that the Govt Sarvodaya Bal Vidyalaya is comprised of Ground + 01 upper floor building thus below 09 mtrs, located at Qutub Road, Delhi 110006 have complied with the fire prevention and fire safety Requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 07/07/2011 in the presence of Vice Principal Sh Mohan Lal and that the building / premises is fit for occupancy of Group B Educational Building Class Sub Div. B-1 (Schools upto Senior Secondary level) with effect from 05/08/2011 for a period of three years, subject to conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements, means of escape facilities shall be maintained in good working condition at all times. Any lapse rendering fire safety systems or means of escape facilities non-functional shall be responsibility of the management.
2. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate shall be null and void.
3. The staff shall be trained for operating fire fighting systems and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.delhigovt.nic.in

Issued on 05/08/11 at New Delhi by



Chief Fire Officer
For Director
Delhi Fire Service

Copy to:

1. The Principal / Manager,
Govt Sarvodaya Bal Vidyalaya,
Qutub Road, Delhi-110006
2. The Director of Education,
Old Secretariat, Delhi