

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001.


No.F6/DFS/MS/2011/ (EH) 1995

Dated-----11/8/11

FIRE SAFETY CERTIFICATE

Certified that the **Amber Restaurant** located at **N-19, Connaught Circus, New Delhi** Comprised of **Ground+ 2 Upper Floors (Restaurant is running at Ground + Mezzanine Floors)** was granted NOC by this department vide letter No **F6/MS/DFS/EH/2010/1748** dated **15/06/10** The premises was re-inspected by the officer concerned of this department on **04/08/11** in the presence of **Mr. L.M.Sandhu** and found that the said Guest House have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule 2010 and that the premises is fit for occupancy class **Assembly Building Group D of Sub Division D-5** with effect from **04/08/11** for a period of **Three** years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi fire Service Rule 2010.

Issued on-----11/8/11-----at New Delhi by.


Chief Fire Officer
Delhi Fire Service

Copy to:-

1. D.E.O. (Restt.), Govt. of NCT of Delhi, Department of Excise,
Entertainment & Luxury Tax L & N Block, I.P.Estate, Vikas Bhawan, New Delhi.

2. Amber Restaurant, N-19, Connaught Circus, New Delhi
Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non- functional shall be the risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010.The form is available on WWW.dfs.Delhigovt.nic.in

References quoted above enclosed by Manager
Amber Restaurant - M-19 Connaught Circus, New Delhi
regarding issuance of NOC for renewal of license issued
by Collector excise G.O.C.T., L & N Block Vikash Bhawan I.P. Estate,
New Delhi

In this regards the inspection of said restaurant
was carried out by APOU on 4.8.11 to verify the
performance of existing fire safety arrangement & observed
as under - Restaurant is being run on G+MF. of building
fire safety arrangement provided such as,

- 1 Water storage tank of 5000 lit cap provided on roof
- 2 Automatic sprinkler system
- 3 Hose Reels
- 4 Manual El call points
- 5 Portable fire extinguishers
6. Emergency lights
- 7 Illuminated Exit signs
- 8 D.B. Set
- 9 Two no of exits for G+MF
- 10 Smoke venting system
- 11 Two no fire pumps 450 LPM & 180 LPM cap

These were checked at random & found functional
at the time of inspection

- N/10 -

FT letter is put up for signature pl

~~epo~~
Dun
1998

Rand
1981/11

MS