

NO. F-6/DFS/MS/GH/2011/1968

Dated: 12/08/2011

FIRE SAFETY CERTIFICATE

Certified that the Guest House Ashoka Continental located at 8370, Arakashan Road, Paharganj, New Delhi comprised of Basement + Ground + four upper floors and terrace is sealed by MCD is having 34 guest rooms (02 + 08 + 08 + 08 + 08 guest rooms), and was granted NOC by this department vide letter No F-6/DFS/MS/GH/2009/2102 dated 15/07/2009, owned / occupied by Sh Ashok Kumar have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 25/07/2011 in presence of Sh Ashok Kumar and that the building / premises is fit for occupancy Class Sub Div. A-1 lodging or rooming houses of group A Residential Building with effect from 12 / 08 / 2011 for a period of three years subject to conditions given below:

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 12 / 08 / 2011 at New Delhi by



Chief Fire Officer
Delhi Fire Service

etc
Maw

Copy to:

1. The Additional Commissioner of Police (Lic),
1st floor, Police Station, Defense Colony, New Delhi for information
2. Sh Ashok Kumar, Guest house Ashoka Continental, Arakashan Road,
Paharganj, New Delhi

Name of guest house: Ashoka Continental
Located at: 8370, Arakashan Road, Paharganj, New Delhi
Starting year: Referred to DFS on 26/03/2001
Inspected by: ADO (JRR) on 25/07/2011 for renewal of license
Width of staircase: 130-135 cms

<u>Floor Details</u>	<u>Rooms used for Guests</u>	<u>Other uses</u>
Basement	-----	01 office + 01 store
Ground Floor	02 Guest rooms	Reception
First Floor	08 Guest rooms	
Second Floor	08 Guest rooms	
Third Floor	08 Guest rooms	
Fourth Floor	08 Guest rooms	
Fifth Floor	-----	Sealed by MCD

Fire safety measures provided

Sprinkler system in the basement	provided & functional
Hose reel with proper boosting arrangements	provided & functional
Fire Extinguishers	provided & functional
Exit Sign	provided & functional
MICB	provided & functional
Manual Call Point	provided & functional
Intercom system	provided & functional
Emergency light	provided & functional
Oil tank	5000-ltr tank
DCI set	provided & functional

Recommendations: - Keeping in view of above renewal of license for 34 guest rooms from fire and safety point of view is recommended.

FL/DI Vis put up for approval and signature please.

20 (cc)
[Signature]
9/8/11

[Signature]
7/8/11

01/8/11
[Signature]
9/8
[Signature]
10/8
[Signature]
10/8

[Signature]
11/8
[Signature]
12/8