

NO. F6/DFS/MIS/GH/2011/1969


Dated: 12/08/2011

FIRE SAFETY CERTIFICATE

Certified that the Guest House Diplomat Inn located at 8227, Gali No -6, Arakashan Road, Paharganj, New Delhi comprised of Ground + four upper floors and terrace is sealed by brick wall is having 13 guest rooms (01 + 03 + 03 + 03 + 03 guest rooms), and was granted NOC by this department vide letter No F-6/DFS/MIS/GH/2009/1253 dated 08/05/2009 is owned / occupied by Sh Kiran Pal Singh and Sathir Singh have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 06/08/2011 in presence of Sh Kiran Pal Singh and Sathir Singh and that the building / premises is fit for occupancy Class Sub Div. A-1 lodging or rooming houses of group A Residential Building with effect from 12/08/2011 for a period of three years subject to conditions given below.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses. If maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 12/08/2011 at New Delhi by


Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Additional Commissioner of Police (Lic), 1st floor, Police Station Defense Colony, New Delhi with letter No 17874/Addl. CP/Lic (H) dated 26/04/2011 for information
2. Sh Kiran Pal Singh and Sathir Singh, Diplomat Inn Guest house, 8227, Gali No 6, Arakashan Road, Paharganj, New Delhi

Reference L.No 17874/Addl. CP/Lic (H) dated 26/04/2011
 Name of guest house **Diplomat Inn**
 Located at 8227, Arakashan Road, **Paharganj, New Delhi**
 Starting year Referred to DFS on 16/04/2001
 Inspected by ADO (JRR) on 06/08/2011 for renewal of license
 Width of staircase 112 - 129 cms

<u>Floor Details</u>	<u>Rooms used for Guests</u>	<u>Other uses</u>
Ground Floor	01 Guest rooms	Reception
First Floor	03 Guest rooms	
Second Floor	03 Guest rooms	
Third Floor	03 Guest rooms	
Fourth Floor	03 Guest rooms	
Terrace floor	-----	Staff room (Sealed with brick wall)

The owner has removed the shortcomings communicated vide this office letter dated 16/06/2011.

Fire safety measures provided

Hose reel system with boosting arrangements	provided & functional
Fire Extinguishers	provided & functional
Intercom system	provided & functional
Emergency light	provided & functional
Exit Sign	provided & functional
MCB	provided & functional
Oil tank and pump	2500-ltr tank
DCI set	provided & functional

Recommendations: - Keeping in view of above renewal of license of the said guesthouse from fire and safety point of view for **13 guest rooms** is recommended.

FT/DEA is put up for approval and signature please.

to (cc) / ~~Handwritten signature~~
9/8/11

Handwritten signature
6/8/11

DC to / 2 ~~Handwritten signature~~
9/8

Handwritten signature

Handwritten signature
10/8

Handwritten signature
11/8