

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI- 110001

NO : F.5/MS/DFS/HQ/ (BA) / 2011 / 192

DATED: 9/8/11

FIRE SAFETY CERTIFICATE

Certified that the Fire works Shop No. 8/3, CSC-12, D-Block, DDA Market Sector-16, Rohini, Delhi comprised of ground floor only thus, have complied with the fire prevention and fire safety requirements in accordance with the guidelines issued by Additional Commissioner of Police (Lic.) and verified by the Officer concerned of Delhi Fire Service on 27/07/2011 in the presence of Shri Ankit Goyal, Proprietor and the shop is fit for running the trade of Sale and Possession of Fire Works chinses cracker 1200 kg & fireworks 300 kg class Fire Works with effect from 9/8/11 for a period of three years.

Issued on9/8/11..... At New Delhi by



Chief Fire Officer
For Director
Delhi Fire Service

Copy to:

1. The Additional Commissioner of Police (Lic.),
1st Floor, Police Station Defense Colony, New Delhi.
W.r.t. Letter No. (PDQ/16)/2010/124-126/Addl.CP/Lic.(Expl.),
dated 3rd January, 2011
2. Shri Ankit Goel, Proprietor,
Shop No. 8/3, CSC-12, D-Block, DDA Market,
Sector-16, Rohini, Delhi

etc

Following fire safety directives must be adhered to:

- 1) All the fire safety arrangements provided there in shall be maintained in good working condition at all times.
- 2) Any loss of life or property due to non functional of fire safety measures shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock when shop is open.
- 4) Any deviation w.r.t. construction etc. shall be verified by concerned building sanctioning authority.
- 5) This certificate may not be treated in any case for regularization of unauthorized construction, if any.

Please refer to your letter No. (PFW/14)/2011/31945-48/Addl.CP/Lic. (Expl.), dated the 6th July, 2011 regarding the grant of Permanent Fireworks License at Shop No. 8/3, CSC-12, D-Block, DDA Market, Sector-16, Rohini. Delhi. In this connection the premises was inspected in the presence of Shri Ankit Goel by the undersigned along with Divisional Officer (Rohini) on 27.07.2011 and found that the premises is ground floor having an area of 22 feet x 10.2 feet.

The owner has provided MCB conduit/ concealed wiring, one Water CO2 and two ABC fire extinguishers of ISI mark, sand buckets and water buckets etc. and they have also provided one emergency exit.

Keeping in view of above, this department has no objection to grant the license for sale and possession of fire works at the said premises from fire safety and fire prevention point of view. If agreed, Fire Safety certificate is put for signature please.

[Signature]
Assistant Divisional Officer (Bawana) 29/7/2011

[Signature]
Divisional Officer (Rohini)

*Decanted for Chinese cracker 1200 kg
Fire works 300 kg.*

[Signature]

[Signature]
218

[Signature]

F. J. Lettner is part w/ for Depositional pl.

[Signature]
5/8/2011

~~CFO~~

[Signature]
5/8

[Signature]