

**FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE**

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI.  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI-110 001.

No. F6/DFS/MS/2011/EH/ 1931

Dated: 10/08/11

**FIRE SAFETY CERTIFICATE**

Certified that the M/S "Khazana Restaurant" at 228, Moment Mall, 3<sup>rd</sup> Floor, 67 Patel Road(Rama Road), New Delhi (A unit of Galaxy Food & Hospitalities) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Services on 30.07.2011 in presence of Sh. Harpal Singh of restaurant and that the premises is fit for **Class D** (Assembly) occupancy with effect from .....10/08/11.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....10/08/11..... at New Delhi by



CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

To

1. The Manager, Khazana Restaurant, 228, Moment Mall, 3<sup>rd</sup> Floor, 67 Patel Road (Rama Road), New Delhi. W.r.t your letter No. D-415/HD/WZ/ dated 09.06.2011
2. Dy. Health Officer, West Zone, MCD, Rajaouri Garden, New Delhi

Note\*:- For general fire safety directives please see overleaf.



May kindly see the letter No. D-415/HD/WZ dated 09.06.2011 received from the DHO regarding issuance of NOC in respect of restaurant, in the name and style "Khazana" located at 228, Moments Mall, 3<sup>rd</sup> floor, 67 Patel Road (Rama Road), New Delhi (A unit of Galaxy Food & Hospitalities).

In this connection it is to inform you that the premises was inspected by the undersigned on 30.07.2011 with a view to ensure the compliance of fire safety system as per the provisions contained in the DFS Act, 2007. The restaurant is proposed at 3<sup>rd</sup> floor in the mall, covering area approx. 500 sq. m. The point wise compliance of fire safety recommendations are given below:

S. No.	Fire safety provisions	Provided/ Not Provided	Remarks
1.	Access to building	Provided	Building approachable
2.	Number, width type and arrangement of exits	Provided	Two exit gates from the restaurant premises (width approx. 2.25 m and 1.5 m.)
3.	Protection of exits by means of fire check door (s) and or pressurization	Provided	In mall
4.	Compartmentation	Provided	In mall
5.	Smoke management system	Provided	In kitchen and mall
6.	Fire extinguishers	Provided	In restaurant premises
7.	First aid hose reels	Provided	In mall
8.	Automatic fire detection and alarming system	Provided	Extended in restaurant premises
9.	MOEF A	Provided	Near to gate
10.	Public address system	Provided	Audible in premises
11.	Automatic sprinkler system	Provided	In restaurant premises
12.	Internal hydrants and yard hydrants	Provided	In mall
13.	Pumping arrangements	Provided	In mall
14.	Captive water storage for fire fighting	Provided	In mall
15.	Exit signage	Provided	In restaurant premises
16.	Provision of lifts	Provided	In mall
17.	Standby power supply	Provided	In mall
18.	Refuge area	Provided	In mall
19.	Fire control room	Provided	In mall
20.	Special fire protection systems for protection of special risks	Provided	In mall

The fire safety systems were operated and found functional. Keeping in view satisfactory compliance, the fire safety certificate may be issued. The "Form H" is put up accordingly for favour of approval please.

*[Handwritten signature]*