

No. F.6/DFS/MS/2011/1909

Dated: 08/08/11

FIRE SAFETY CERTIFICATE

Certified that the **KIIT World School (New State Academy Sr. Secondary School)** is comprised of ground and three upper floors only at Pitampura, Delhi-110034 was granted NOC vide letter no. F.6/DFS/MS/2007/3805 dated 24.12.2007. The premises was re-inspected by the officer concerned of Fire Service on 22.07.2011 in the presence of Smt. Sangeeta Bhatia (Principal), KIIT World School and that the building/premises is fit for occupancy Class B (**Educational**) with effect from 08/08/11 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on08/08/11..... at New Delhi by.



(A.K.SHARMA)

DIRECTOR

Delhi Fire Service

OK
A.S.



To :

The Manager,
KIIT WORLD SCHOOL
ZONE H-4 Pitampura
Delhi-110035.

Copy to :-

The Director of Education
Old Secretariat,
Delhi

may kindly see the letter no. KII/521/11 dated 07.07.2011 received from Smt. Sangeeta Bhatia (Principal), KII World School (New State Academy Sr. Secondary School), at Pitampura, Delhi-110034. Wherein NOC issued earlier vide letter no. F.6/DFS/MS/2007/3805 dated 24.12.2007 is requested to be renewed.

In this connection it is to inform you that the above said premises has been re-inspected by the officer concerned of this department on 22.07.2011. It was observed that the school building is comprised of ground and three upper floors only.

The point wise compliance of fire safety recommendations, in accordance with the Delhi Fire Service Act – 2007 and rules 2010 are given below :-

S.No.	Fire Safety provisions	Provided/Not Provided	Remarks
1.	Access to building	Provided	
2.	Number, width type and arrangement of exits	Provided	2 nos. of staircases in the building of width 1.5 mtr. each.
3.	Protection of Exits by means of fire check door (s) and or pressurization	Not required	Stairs open to outside.
4.	Compartmentation	Not required	
5.	Smoke Management System	Not required	
6.	Fire Extinguishers	Provided	12 nos. ABC type ISI mark cap. 5 kg.
7.	First Aid Hose Reels	Provided	8 nos. of hose reel (2 nos. on each floor) of 30 mtrs. length each fitted with 0.5 mm dia nozzle .
8.	Automatic Fire detection and alarming system	Not required	
9.	MOEF A	Provided	
10.	Public Address System	Provided	
11.	Automatic Sprinkler System	Not required	
12.	Internal Hydrants and Yard Hydrants	Provided	8 nos. (2 nos. on each floor) with two hose & Branch in hose box.
13.	Pumping Arrangements	Provided as per recommendations	On terrace two pumps cap. 900 lpm & 1800 lpm as jockey.
14.	Captive Water Storage for fire fighting	Provided	O.H. tank cap. 10,000 ltrs. & U.G. tank cap. 20,000 ltrs.
15.	Exit Signage	Provided	
16.	Provision of Lifts	Not required	
17.	Standby power Supply	Not required	
18.	Refuge area	Not required	
19.	Fire Control Room	Not required	
20.	Special Fire Protection Systems for Protection of Special Risks	Not required	

Keeping in view satisfactory compliance the fire safety certificate may be renewed. The " Form H" is put up accordingly for favor of approval please.