

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTER: DELHI FIRE SERVICE, NEW DELHI-110001

NO. FG/DFS/MS/GH/2011/1946

Dated: 11/8/2011

To,

The Addl. Commissioner of Police (Lic)

1st Floor P.S. Defence Colony

New Delhi

Sub:-Regarding addition of 2 dormatry in the license in r/o Laxmi Bilas Marwari Guest House, P.No- 178-179, C.M. Road, Fatehpuri Delhi-110006

Sir,

Please refer to your letter no: - 30938/Addl C.P/Lic. (H) Dated:-30/06/2011 on the subject cited above. In this connection it is to inform you that the above said premises was inspected by the officer concerned of this department on 18/07/2011 from fire safety point of view. Sh. Umakant Sharma was present at the time of inspection.

During the course of inspection it has been observed that the guest house is located on the main road and easily approachable to the fire engine. The building is comprised of ground + two upper floors. The ground floor is being used as commercial purpose. The 1st floor is having 2 guest rooms + Reception. The 2nd floor is being used as one guest room. The building is served with 2 Nos of stair case having width 78 and 85 cms. The owner of the guest house want to add 2 Nos of dormatry on 1st and 2nd floor which was earlier used as storage and dining purpose. The electric wiring laid through conduct type & MCB also installed there. The existing fire safety arrangements provided such as Fire Existnguisher of different types & Cap illuminated exit sign, Emergency light were checked/tested and found in satisfactory working condition.

In view of the above satisfactory fire safety arrangement provided by the management. This department have no objection for the addition of 2 dormatry with 3 Nos of guest rooms from fire safety point of view. However the management is advised to maintain the existing fire safety arrangement in good working order as seen during inspection.

C.C.to

Sh. Umakant Sharma

Laxmi Bilas Marwari Guest House

178-179, C.M. Road

Fatehpuri Delhi

Yours Faithfully


9/8
Chief Fire Officer

Delhi Fire Service



(H) dt-20/1/2011 received from Addl. C.P.(lic) regarding Addition of 2 dormitory in the license in 40 Cassini Bidas Marwari Guest house. at 178-179, C.M. Road Fatehgarh Delhi 6. In this regard an inspection was carried out by the undersigned on 18/7/2011 from fire safety point of view. Sh. Umakant Sharma was present at the time of inspection.

During the course of inspection it has been observed that the Guest house is located on the Main Road of 30' wide. The Bldg. is comprised of Ground + 2 upper floors. The Ground floor is being used as Commercial purpose. The 1st floor is having 2 Guest rooms + Reception. The 2nd floor is being used as one Guest room. The bldg. is served with 2 nos of Stair Case having width 7'8" & 8'5" C.M.. Now the owner of the Guest house want to add 2 nos of dormitory i.e. one on 1st and 2nd floor which was earlier used as Storage and Dining purpose. The Elec. Wiring were seen Conduit type. MCB also installed there.

Exit : Provided 2 stair cases
width 78 & 85 C.M.

Protecting Exit :- Not Required.

Compartmentation :- Not Required.

Smoke Management System :- Provided Exhaust fan.

Fire Extinguisher :- Provided 1-5-1 marked water based type at each floor.

Fire Airtight seal :- Not Required

Automatic detection system :- Not Required.

MOEFA — Not Required.

P.A. System — Not Required.

Automatic sprinkler system — Not Required.

Internal Hydrant — Not Required

Lumping Arrangement — Not Required.

Reserve water storage — Not Required
Provided at each

18) Refuse Area - NOT Required.

19) Fire Control room - NOT Required.

20) Spr. fire protection - NOT Required.

The above mentioned fire safety arrangements were checked/tested and found in satisfactory working condition.

In view of the above satisfactory fire safety arrangement provided by the management NOC for the addition of 2 nos of dormitory with 3 guest rooms is recommended. IFA on the above lines is placed opp. side in the file for approval & sign. Mr.

By Mr. 

Submitted Mr.

Shree

30/7/11

cap 318

318

Mr. 
318