

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001

No F6/DFS/MS/GH/2011/1920

Dated 10/08/11

FIRE SAFETY CERTIFICATE

Certified that the Mansha Residency D – 55, East of Kailash, Opp. Sapna Cinema, New Delhi. The Guest House is being run at first & second floors with 15 Guest Rooms of the bldg. which comprises basement, ground & three upper floors. Basement, ground & third floor are others property, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 29 -6 - 2011. and that the premises is fit for occupancy of Guest House with effect from 10 - 8 -2011 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed overleaf.

Issued on 10/08/11 at New Delhi.



Chief Fire Officer
Delhi Fire Service

Copy to :-

The Partner

Mansha Residency G / House

D – 55, East of Kailash,

Opp. Sapna Cinema,

New Delhi.

Ref: - Letter No --NIL-- dated 13/6/11 (Dy 6262)

With ref. above quoted letter, premises have been ~~vis~~ inspected by ADD (NS) in the presence of manager on 28/6/11.

During inspection, it was observed that the Prop. is owning Guest House at first & second floor of the bldg. which comprises, basement, ground & three upper floors. The occupancy floorwise was seen as under.

Basement	—	Storage & office	} others for party
Ground	—	Office	
First fl.	—	08 G) Rooms, Rec.	}
Second fl.	—	07 G) Rooms, D. room, Pantry.	
Third fl.	—	Institute (others for party)	

The bldg. is provided with two nos staircase, one is 1.0 mtr. wide & another for first & second floor of iron made of 1.25 mtr. width. Other details as per 20 point is given as under.

- 1 Access — Available (60' wide road.)
- 2 No. width, Type of Exits — 2 Nos. 1.0 mtr. internal.
1.25 mtr. External for I & II (iron made)
- 3 Protection of Exit by FCD — Not reqd.
- 4 Compartmentation — Provided.
- 5 Smoke Management System — Not required.

- 14. Captive water storage — Not required.
- 15. Exit signs — Provided
- 16. Provision of lift — Not required
- 17. Standby Power Supply — Not required but provided.
- 18. Refuge Area — Not required.
- 19. Fire Control Room — Not required
- 20. Spl. fire protection for spl. risk — Not required.

In view of the above issuance of fire Safety Certificate is recommended and accordingly draft fire safety Certificate is put up for perusal & approval.

Submitted please.

Urshant
2/8/11

DO (BOP) [Signature]
4/8/11

D (BOP) [Signature]
5/8

CFO [Signature]
5/8

Air [Signature]
8/8

cc-ndt
8-11