

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI-110 001

No. F.6/DFS/MS/2011/1986

Dated: 12/08/11

FIRE SAFETY CERTIFICATE

Certified that the **Mata Shiv Devi Public School** comprised of basement, ground and three upper floors only at A-2, Keshav Puram, Delhi-110035 was granted NOC vide letter no. F.6/DFS/MS/2007/1463 dated 29.05.2007. The premises was re-inspected by the officer concerned of Fire Service on 05.07.2011 in the presence of Sh. Budh Prakash (Manager), Mata Shiv Devi Public School and that the building/premises is fit for occupancy Class B (**Educational**) with effect from 12/08/11 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on ...12/08/11..... at New Delhi by.


(A.K.SHARMA)
DIRECTOR
Delhi Fire Service

To:

The Manager,
Mata Shiv Devi Public School,
A-2, Keshav Puram,
Delhi-110035.

Copy to :-

The Director of Education
Old Secretariat,
Delhi

etc


7/7

May kindly see the letter no. F.M.S.D./EX/DFS/2011 dated 06.06.2011 received from Sh. Budh Prakash (Manager), Mata Shiv Devi Public School at A-2, Keshav Puram, Delhi-110035. Wherein NOC issued earlier vide letter no. F.6/DFS/MS/2007/1463 dated 29.05.2007 is requested to be renewed.

In this connection it is to inform you that the above said premises has been re-inspected by the officer concerned of this department on 05.07.2011. It was observed that the school building is comprised of basement, ground and three upper floors only.

The point wise compliance of fire safety recommendations, in accordance with the Delhi Fire Service Act – 2007 and rules 2010 are given below :-

S.No.	Fire Safety provisions	Provided/Not Provided	Remarks
1.	Access to building	Provided	
2.	Number, width type and arrangement of exits	Provided	<u>2 nos. of staircase</u> in the building. <u>with</u>
3.	Protection of Exits by means of fire check door (s) and or pressurization	Not required	<u>1.25 mts each</u>
4.	Compartmentation	Not required	
5.	Smoke Management System	Not Required	
6.	Fire Extinguishers	Provided	8 nos. ABC type ISI mark cap. 5 kg & 5 nos. Wco2 type cap. 9 ltr. ISI mark.
7.	First Aid Hose Reels	Provided	3 nos. of 30 mtrs. length each fitted with 0.5 mm dia nozzle .
8.	Automatic Fire detection and alarming system	Not required	
9.	MOEF A	Provided	
10.	Public Address System	Provided	
11.	Automatic Sprinkler System	Provided in basement	
12.	Internal Hydrants and Yard Hydrants	Provided	3 nos. <u>with two</u> hose & Branch in <u>ho</u> se box.
13.	Pumping Arrangements	Provided as per recommendations	On <u>terrace</u> two pump cap. 450 lpm & 180 lpm as jockey. <u>→</u>
14.	Captive Water Storage for fire fighting	Provided	O.H. tank cap. 5000 ltrs. <u>→</u>
15.	Exit Signage	Provided	
16.	Provision of Lifts	Not required	
17.	Standby power Supply	Not required	
18.	Refuge area	Not required	