

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001

No F6/DFS/MS/EH/2011/1949

Dated 12/08/11

FIRE SAFETY CERTIFICATE

Certified that the Mc. Donald Restaurant, Shop No. 1, GF, Satyam Cinema, N. Place, New Delhi is being run at ground floor of the bldg. which comprise of basement, ground & two upper floors, was granted NOC by this deptt. vide letter No. F6 / DFS / MS / EH / 2007 /961 / dated 2-4-2007. The premises was re-inspected by the officer concerned of this department on 6-8-2011 in the presence of Mr. Kukreja & other technical staff members, have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of Restaurant at ground floor with effect from 12-8-2011 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed overleaf.

Issued on 12/08/11 at New Delhi.



Chief Fire Officer
Delhi Fire Service



Copy to :-

1. The Authorized Signatory,
Mc. Donalal Restaurant,
Shop No. 1, GF, Satyam Cinema,
N. Place, New Delhi.
2. The Dy. Health Officer
MCD, Central Zone,
Lajpat Nagar, New Delhi.

Ref: - Letter No. NIL- dated 5/7/11 (Dy 7225)
Copy of Letter No DHO/C2/2011/798 dt 20/6/11

With ref. above quoted letter, it is submitted that the said Restt. was issued NOC by this Deptt. vide letter No F6/DKS/ms/EH/2007/96) dated 02.4.2007 on the basis of below mentioned fire protection measures.

1. Access — Available
2. Hose Reels — Provided.
3. Internal hydrant & yard hydrant — Provided (wet Riser)
4. Fire Extinguishers — Provided (ABC, CO₂ type)
5. Emergency Lights — Provided (battery backup)
6. Exit Signs — Provided.
7. Smoke Venting — Provided.
8. Stand by Power Supply — Provided in bldg.
9. MIOEFA — Provided.
10. Automatic fire detection & alarming system — Provided.
11. Automatic sprinkler system — Provided.
12. Electric installation — Concealed Type MCCB & ELCB - Provided.
13. Captive water Storage. — Already provided in bldg. (OHT & UG)
14. Fire Pumps — Already existing

That there is no addition/alteration in the construction in the premises for which NDC was issued by this dept.

The above mentioned fire fighting arrangements were checked and found functional at the time of inspection.

In view of the above general of fire safety certificate is recommended and accordingly fire safety certificate is put up for perusal & sign, if approved.

Submitted please.

W. S. K. S.
3/8/11

DO (BSP)

[Signature]
9/8/11

By CFO on c/z
CFO

[Signature]
11/8

FT [Signature]

[Signature]
11/8

[Signature]

FT Fire safety certificate is put up for signatures, please.

[Signature]
11/8/11