

NO. F6/DFS/MS/2011/1983

Dated: 12/08/2011

FIRE SAFETY CERTIFICATE

Certified that the M C Model School is comprised of Ground floor cemented shed building thus below 09 mtrs, located at Loco Shed-I, Kishan Ganj, Delhi 110006 have complied with the fire prevention and fire safety requirements in accordance with the circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 21/07/2011 in the presence of Headmistress M C Model School and that the building premises is fit for occupancy of Group B Educational Building Class Sub Div. B-1 (Schools upto Secondary level) with effect from 12/08/11 for a period of three years, subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements, means of escape facilities shall be maintained in good working condition at all times. Any lapse rendering fire safety systems or means of escape facilities non-functional shall be responsibility of the management.
2. Building sanctioning authority may verify any deviation with regard to the construction occupancy in the building. In case of any deviation, the fire safety certificate shall be null and void.
3. The staff shall be trained for operating fire fighting systems and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on 12/08/11 at New Delhi by



Chief Fire Officer  
For Director  
Delhi Fire Service

Copy to:

1. The Headmistress,  
M C Model School,  
Loco Shed-I, Kishan Ganj,  
Delhi-110006
2. The Director of Education,  
Old Secretariat, Delhi



Sub: -Regarding issuance of NOC from fire safety point of view in respect of M.C. Model School, Loco Shed-1, Kishan Ganj, New Delhi-110006

Please refer to letter No Nil dated 22/03/2011 on the subject cited above. In this connection the premises was visited by the officer of this department and observed that the school is run on Ground floor only and is built on approx 1000 sq yards area with 06 rooms and 194 students. **The school is approachable to fire units.**

The fire safety arrangements such as two fire extinguishers of ABC type 05 Kg capacity and two sand buckets and two water buckets, conduit / concealed wiring, MCB etc were seen provided.

The premise is **meeting the requirements** of Director of Education circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011.

In view of above NOC from fire and safety point of view is recommended.

DO (CC) on leave

DC/DO  
CC/O

Sun  
3/8  
Am  
2/8

FT  
flam  
Am  
2/8

FT is put up please.

Am

Am  
2/8/11

Am  
29/7/11  
2/8/11