

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
 HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
 NEW DELHI- 110001

NO. F6/DFS/MS/2011/1934

DATED: 10/08/11

FIRE SAFETY CERTIFICATE

Certified that the M/s MKW Hospital building, at J-Block, Community Centre, Rajouri Garden, New Delhi-110027 comprising of basements, ground plus three upper floors was granted NOC by this department vide letter no. F.6/DFS/MS/97/Hospital/255 dated 10.03.1997. The premises was re-inspected by the officer concerned of this department on 22.07.2011 in the presence of Mr. Suresh Wahi (Medical Superintendent), of the hospital and that the building is fit for occupancy class "Hospital building" with effect from...10/08/11... for a period of **three** years, printed overleaf.

Issued on ...10/08/11... at New Delhi by



Chief Fire Officer
 Delhi Fire Service

9/2

1. Jt. Director, (L&I) Bldg.,
 DDA Bldg, Vikas Sadan,
 INA, New Delhi
2. The Authorized Signature,
 MKW Hospital, Plot No. 12, J-Block,
 Community Centre, Rajouri Garden,
 New Delhi-110027

May kindly peruse the letter No. 105/MKW/F/12 dated 22.03.2011 received from the Authorized Signature, MKW Hospital, Plot No. 12, Community Centre, Rajouri Garden, New Delhi-110027, regarding **renewal** of NOC from fire safety point of view in r/o MKW Hospital, Plot No. 12, Community Centre, Rajouri Garden, New Delhi-110027. In this connection, it is stated that the above said premises has been inspected by D.O Than Singh along with D.O Dharam Pal Bharadwaj with the view to see the compliance of fire safety.

During the course of inspection it was observed that above said Hospital is comprised basements, ground plus three upper floors on a plot area of about 375 sq. mtrs. The hospital building is accessible for fire vehicles through a road of sufficient width. The point-wise compliance of fire safety requirements is given below:

S.No.	Fire Safety Provisions	Provided / Not provided	Remarks
1.	Access to building	Provided	Main road.
2.	Number, Width Type Arrangement of exits	Provided	Staircase : 1 No.(width of stair- 125 cm)
3.	Protection of Exits	Provided	Fire check doors are provided in staircase
4.	Compartmentation	Provided	All vertical and horizontal openings are found sealed with non-combustible material.
5.	Smoke Management System	Provided	Exhaust fans are found provided in basement.
6.	Fire Extinguishers	Provided	Two CO2 fire extinguisher having capacity 4.5 kg and three ABC type having capacity 5 Kg. ISI mark are found provided at each floor level.
7.	First-Aid Hose Reels	Provided	Hose reel in each floor level directly connected to main down comer.
8.	Automatic fire detecti alarming system	Provided	Smoke detectors are found provided in entire building.
9.	MOEFA	Provided	Nearl staircases at each floor.
10.	Public Address Syste	Provided	PA system is provided.
11.	Automatic Sprinkler System	Provided	Sprinklers are found provided in basement.
12.	Internal Hydrants and Yard Hydrants	Provided	Dwon comer system found provided.
13.	Pumping Arrangeme	Provided	The fire pumps having capacity 900 LPM and one jockey pump having 180 LPM at 40 meters head in auto operation are found installed at terrace.

14	Captive Water Storage for fire fighting	Provided	An over head water storage tank having capacity 10,000 ltrs. and under ground water having capacity 30,000 ltrs. are found provided.
15	Exit Signage	Provided	Exit signage near staircase.
16	Provision of Lifts	Provided	The Lifts are found equipped with firemen switch & communication system also found provided.
17	Standby power supply	Provided	Found provided.
18	Refuge Area	Not Required	
19	Fire Control Room	Not required.	
20	Special Fire Protection Systems for Protection of special Risks	Not required.	

The above said fire safety equipments are found functional at the time of inspection.

In view of the above, the hospital building may be considered for **renewal** of (NOC) fire safety certificate from the fire safety point of view. This department had already issued NOC for the hospital building vide letter no. F.6/DFS/MS/ 97/Hospital/255 dated 10.03.1997. The draft fire safety certificate on form H is placed on file for approval and signatures.

Submitted Please.

D.O.
(Dharampal Bhardwaj)

D.O.
(Moti/Nagar)

desha
5/8/2011

D. CFO
8/8

CFO