

No F-6/DFS/MS/2011/1940

Dated 11/08/11

**FIRE SAFETY CERTIFICATE**

Certified that the New Green Field School Alaknanda (Kalkaji) Near Tara Apartment, New Delhi. comprising basement, ground & three upper floors with 64 rooms have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 25 - 7 - 2011 in the presence of Sh. Ashish Kalra (Admin) and that the premises is fit for occupancy class Education with effect from 11-8-2011 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. subject to conditions printed overleaf.

Issued on 11/08/11 at New Delhi.



Chief Fire Officer  
Delhi Fire Service

Copy to :-

1. The Manager  
New Green Field School  
Alaknanda (Kalkaji)  
Near Tara Apartment, New Delhi.
2. Dy. Director Education  
G N C T D, C- Block,  
Defence Colony,  
New Delhi.



Ref: Letter No -NIL- dated 15/6/11 (by 6355)

With ref. above quoted letter, school premises have been inspected by ADO (NP) on 25/7/11 in the presence of Sh. Ashish Kalra (Admin) to verify the ~~the~~ shortcomings as communicated vide our letter dated 27.11.09.

During inspection, it was observed that the management is running school in the 2<sup>nd</sup> bldg. blocks and both the blocks are interconnected at each floor level. The bldg. is provided with two nos. staircase of 1.5 mtr & 1.40 mtr width. Total 64 rooms are provided in the bldg. The bldg. abuts on road of 60' (approx.). Detail report on para 20 points was seen as under. Imp. emergency tel. nos. displayed on notice board.

1. Access — Available ✓
2. No. width, Type of Exits — 02 Nos, 1.5 & 1.40 mtr, Internal.
3. Protection of exits by FCO — Not required.
4. Compartmentation — Provided. ✓
5. Smoke Management — Provided exhaust fans provided in basement.
6. Fire Extinguishers — Provided (W cor & cor) & ABC Type ✓
7. First Aid Hose Reels — Provided each floor. ✓
8. Automatic fire det. & alarming — Not required
9. ~~MAKED~~ — Not required.

- 15. Exit Signs — Not required.
- 16. Provision of lift — Not required.
- 17. Stand by power supply — Provided.
- 18. Refuge Area — Not required.
- 19. Fire control room — Not required.
- 20. Spl. fire protection for spl. risk. — Not required.

The above fire fighting equipments were checked and found functional during inspection.

In view of the above, draft fire safety certificate is placed on file for approval.

Submitted please

15/8/11

DO (BCP) 4/8/11

DLF/2 5/8

CFO

Phase speak on Capacity of  
OHT & pumps for a G+3 building  
including basement

DO (BCP) Spoken

5/8

~~Mr~~ Wms  
9/8

~~Mr~~ F.T. letter is put up for sig. pl.

~~C.F.O.~~ Wms  
11/8

Wms  
10/8/11

NAC