

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DAS/MS/School/2012/1346 Dated: 13/04/2012

FIRE SAFETY CERTIFICATE

Certified that the M.C.Primary School, is comprised of four blocks of Ground floor tin shed S P S rooms thus below 09 mtrs, located at M Block, Raghubir Nagar-1, New Delhi-110027 have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 02/03/2012 in the presence of Mrs Sushma Tyagi, Principal and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 13/04/12 for a period of three years, subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 13/04/12 at New Delhi by


12/4
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal, M.C.Primary School, M Block, Raghubir Nagar-1, New Delhi-110027
2. The Director of Education, Old Secretariat, Delhi
3. The Director of Education, MCD
Civic Centre, Minto Road New Delhi.

INSPECTION REPORT

(ID-1556074)

(Four Blocks of GF Lm Shed (SFS) Rooms)

1. Name & address of the building : MC Primary School, M Block, Raghbir Nagar, F, New Delhi - 27
2. Type of Occupancy : Educational/school
3. Type of Case : New Case / ~~Renewal~~
4. Details of previous NOC : Letter No. — Dated: —
5. Fire Safety directives letter No : Dir of Education letter dtd 1/3/11
6. Date of inspection : 02/03/2012
7. Name of the Inspecting Officers : ADO S S Tuli
8. Name and designation of officers from the building side : Mrs Sushma Tyagi, Principal
9. Year of Construction : —
10. Applicant's letter No. : NIL dtd 22/12/2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	Provided	m/R
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	—	—	—
	• Basements	—	—	—

	b. Width of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1 mtr	Provided	m/n
3	Compartmentation.	N/A	N/A	N/A
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4	Smoke Management System.	N/A	N/A	N/A
	• Basements	30 a/c per hour	-	-
	• Upper floors	12 a/c per hour	-	-

	<ul style="list-style-type: none"> Total numbers Types IS marking 	ISI marked	06	m/R
			ABC Type	m/R
			yes	m/R
6	First-Aid Hose Reels.			
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	— — —	— — —
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	— — — — —	— — — — —	— — — — —
8	MOEFA			
		—	—	—
9	Public Address System.			
		—	—	—
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	— — —	— — —	— — —

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	-	-	-
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19	Fire Control Room	N/A	N/A	N/A
	• Detector System Panel	-	-	-
	• Flow Switch Panel	-	-	-
	• PA System Panel	-	-	-
	• Batter backup	-	-	-
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

DO (M/N) *[Signature]*

Signature of the Inspecting Officer

Name

Designation

[Signature]
2/3/12
SS Tuli
ADO (MN)