

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No: *F6/265/ms) Banquet/2012/1245*

Dated: *10/04/12*

FIRE SAFETY CERTIFICATE

Certified that the Star Banquet located at DMRC Station, ISBT, Kashmere Gate, Delhi-110006 comprised of Ground floor owned / occupied by M/s Star Banquet have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 28-03-2012 in the presence of Mr. Sethi and that the building / premises, is fit for occupancy class Group D, Assembly building (banquet / Party Hall) with effect from *10/04/12* for a period of 03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued *10/04/12* at New Delhi by.



CHIEF FIRE OFFICER
for DIRECTOR
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.),
First Floor, P.S. Defence Colony, New Delhi – 110049
2. M/s Star Banquet, DMRC Station, ISBT, kasmere Gate, Delhi-110006.

*etc
mew*

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

- Star Banquets, Hall No. 17 & 18
 Parymath Metro Mall, Kashmir Gate
 Metro station, Mori Gate side, Delhi-110006
1. Name & address of the building : _____
 2. Type of Occupancy : Assembly Building
 3. Type of Case : New Case/ Renewal
 4. Details of previous NOC : Letter No. - N.A - Dated: -
 5. Fire Safety directives letter No : F6/DF.S/M.8/2011/2030 dt 19-08-11
 6. Date of inspection : 28-03-12
 7. Name of the Inspecting Officers : Dharmvir Singh Yadav
 8. Name and designation of officers from the building side : Mr Sethi
 9. Year of Construction : 2003
 10. Applicant's letter No. : NIL

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement <i>As per BBL 1983</i>	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 Mtes	more than 09 Mtes	M.R
	• Gate width	05 Mtes	Barrier provided width 05 Mtes	M.R
	• Width of internal road	06 Mtes	06 Mtes	M.R
2	Number, Width, Type & Arrangement of Exits	<i>star Banquets located at G.F only.</i>		
a.	Number of staircases			
	• Upper Floors			
	• Basements			
b.	Width of staircases			
	• Upper Floors			
	• Basements			
c.	Protection of exits			
	• Fire check door			
	• Pressurization			
e.	No. of continuous staircases to terrace			
g.	Width of Corridor			
h.	Door Size	01.5 Mtes	4 nos 2 mtes (one) 1.88 mtes (three)	M.R

contd:-

Star Banquets, Hall No. 17 & 18,
 Pansav Nath, Metro Mall, Kashmeri Gate
 Metro station, Mori Gate side, Delhi-110006.

3	Compartmentation.			
	• Fire check door	not required	not provided	M.R
	• Sealing of electrical shafts	- " -	- " -	- " -
	• Fire Rating of shaft door	- " -	- " -	- " -
	• Water Curtain	- " -	- " -	- " -
	• Fire Dampers	- " -	- " -	- " -
4	Smoke Management System.			
	• Basements	30 a/c per hour	- N.A -	- N.A -
	• Upper floors	12 a/c per hour	Yes at G. floor Exhaust Fans provided.	M.R.
5	Fire Extinguishers			
	• Total numbers		12 Nos.	M.R
	• Types		A.B.C, CO ₂ & W. CO ₂ type	M.A
	• IS marking	ISI marked	yes	M.R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	Two	Two	M.R
	• Length of hose reel hose	30 m	yes	M.R
	• Nozzle diameter	5 mm	yes	M.R
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke	Smoke detected	M.R
	• Location of Main Panel	G. floor.	G. Floor	M.R
	• Location of Repeater Panel	-	control room of DM RC	M.R
	• Alternate source of power	-	connected with DM RC supply	M.R
	• Hooters' Location	-	inside Banquet Hall	M.R
8	MOEFA	Required	provided	M.R
9	Public Address System.	- " -	provided.	M.R
10	Automatic Sprinkler System.			
	• Basement	- " -	N.A	-

contd.

Star Banglades, Hall No 17 & 18,
 Pansav Nath metro mall, Kashmiri Gate,
 metro station, Mori Gate side, Delhi-110006

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N.R	Provided	N.R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N.R		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	Common with D.M.R.C		
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	Common with D.M.R.C		

contd.

Star Banquets, Hall No. 17 & 18,
 Parasnath metro mall, Kashmere Gate metro station,
 Mori Gate side, Delhi-110006.

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		/	
15	Exit Signage.	Required	Provided	M.R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N.A	/	
17	Standby power supply		connected with D.M.R.C	M.R
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N.A	/	
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		common with D.M.R.C	
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A	/	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... contd:.....

Star Banquets, Hall no 17 & 18, (5)
Passwanath metro mall, Kashmir Gate
metro station, Mori Gate Side, Delhi-110006.

Signature of the Inspecting Officer

Name

Designation

D. Singh
22-03-12
Signature of the Inspecting Officer

Name *Dharmvir Singh Yadav*

Designation *Assistant Divisional
Officer
(Central)*