

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2012 / 1284

Dated 11/04/12

FIRE SAFETY CERTIFICATE

Certified that the Shri Guru Jambheshwar Sansthan Bhawan, at Civil Line, behind I.P. College, New Vikas Bhawan II, Upper Bela Road, Delhi comprised of Basement + Ground +03 Upper floor was inspected by DO Atul Garg & ADO D.S. Yadav on 02.04.2012 in the presence of Mr. Hanuman Singh and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Residential Building" with effect from - 11/04/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on11/04/12... at New Delhi by.



Chief Fire Officer
For Director
Delhi Fire Service

o/a

Copy to:-

1. The Executive Engineer (B) HQ, MCD, Bldg, Deptt. Town Hall, Delhi.
2. The President, The All India Bishnoi Mahasabha, upper Bela Road, Mahatma Gandhi Marg, Near I.P. College and Metcalf House, Delhi - 110054.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Shri Guru Jambeshwar Sansthan Bhawan, at Civil Line
Behind I.P College, New Vikas Bhawan II, Upper Bela
Road, Delhi – 110054.
2. Type of Occupancy : Residential
3. Type of Case : New Case
4. Details of previous NOC : Letter No Nil
5. Fire Safety directives Letter No. : F6/MS/DFS/BP/2001/1714 Dated 22.08.2001
6. Date of inspection : 02.04.2012
7. Name of the Inspecting Officer : ADO D.S. Yadav & DO Atul Garg
8. Name and designation of Officer
from the building side : Sh. Hanuman Singh
9. Year of Construction : N/A
10. Applicant's letter No. : AIBM/SGISB/Delhi-2012/F-2677 Dated 16.01.2012

| S No | Minimum standards on fire prevention and fire safety U/R 33 | BBL Requirements | Provided at site | Remarks MR/NMR |
|------|---|------------------|------------------|----------------|
| 1. | Access of building | | | |
| | • Road width | 9 m | 12 m | MR |
| | • Gate width | 5 m | 5 m | MR |
| | • Width of internal road | 3m | 6 m | MR |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 02 | 02 | MR |
| | • Basements | 02 | 02 | MR |
| | b. Width of staircases | | | |
| | • Upper floors | 1.25 m | 1.5 m | MR |
| | • Basements | 1.25 m | 1.4 m | MR |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No of continuous staircase to terrace | 01 | 01 | MR |
| | e. Width Of Corridor | 1.25 | 1.25 | MR |

| | | | | |
|-----|--|-----------------|----------------------|-----|
| | f. Door Size | N/A | N/A | N/A |
| 3. | Compartmentation | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | YES | YES | MR |
| | • Fire Rating of shaft door | N/A | N/A | N/A |
| | • Water Curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke managements System | | | |
| | • Basements | 30 a/c per hour | YES | MR |
| | • Upper floors | 12 a/c per hour | N/A | N/A |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | | 20 | MR |
| | • Types | | WT, WCO ₂ | MR |
| | • IS marking | ISI marked | YES | MR |
| 6. | First – Aid Hose Reels | | | |
| | • Total numbers on each floor | 01 | 01 | MR |
| | • Length of hose reel hose | 30 m | YES | MR |
| | • Nozzle diameter | 5 mm | YES | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | YES | YES | MR |
| | • Location of Main Panel | At entrance | YES | MR |
| | • Location of Repeater Panel | Each floor | YES | MR |
| | • Alternate source of power | YES | YES | MR |
| | • Hooters' Location | Each floor | YES | MR |
| 8. | MOEFA | N/A | YES | MR |
| 9. | Public Address System | YES | YES | MR |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | YES | YES | MR |
| | • Upper Floor | N/A | N/A | N/A |
| | • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down- comer | 100 m | YES | MR |
| | • Number of hydrants per floor | 1 | YES | MR |
| | • Hose Box | 1 | YES | MR |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |

| Pumping Arrangements | | | | |
|----------------------|--|------------|------------|-----|
| | <ul style="list-style-type: none"> • Ground Level | | | |
| | <ul style="list-style-type: none"> • Discharge of main pump | 2280 lpm | 2280 lpm | MR |
| | <ul style="list-style-type: none"> ➤ Head of main pump | 60 m | 60 m | MR |
| | <ul style="list-style-type: none"> ➤ Number of main pumps | 01 | 01 | MR |
| | <ul style="list-style-type: none"> ➤ Jockey pump out put | 180 lpm | 180 lpm | MR |
| | <ul style="list-style-type: none"> ➤ Jockey pump head | 60 m | 60 m | MR |
| | <ul style="list-style-type: none"> ➤ Standby Pump out put | 2280 lpm | 2280 lpm | MR |
| | <ul style="list-style-type: none"> ➤ Standby Pump Head | 60 m | 60 m | MR |
| | <ul style="list-style-type: none"> ➤ Auto Staring/Manual stopping | YES | YES | MR |
| | <ul style="list-style-type: none"> ➤ Pump House Access | YES | YES | MR |
| | <ul style="list-style-type: none"> • Terrace level | 900 Lpm | YES | MR |
| | <ul style="list-style-type: none"> ➤ Discharge of pump | 30 mtr | YES | N/A |
| | <ul style="list-style-type: none"> ➤ Head of the pump | YES | YES | MR |
| | <ul style="list-style-type: none"> ➤ Power supply | YES | YES | MR |
| | <ul style="list-style-type: none"> ➤ Auto starting of pump | YES | YES | MR |
| 14. | Captive water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> • Under ground tank capacity | 50,000 ltr | 50,000 ltr | MR |
| | <ul style="list-style-type: none"> ➤ Draw of connection | YES | YES | MR |
| | <ul style="list-style-type: none"> ➤ Fire service inlet | YES | YES | MR |
| | <ul style="list-style-type: none"> ➤ Access to tank | YES | YES | MR |
| | <ul style="list-style-type: none"> • Overhead Tank capacity | 20,000 ltr | 20,000 ltr | MR |
| 15 | Exit Signage | YES | YES | MR |
| 16. | Provision of Lifts | | | |
| | <ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Pressurization of lift lobby | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Communication in lift Car | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Fireman's Grounding Switch | YES | YES | MR |
| | <ul style="list-style-type: none"> ➤ Lift Signage | YES | YES | MR |
| 17. | Standby power supply | YES | YES | MR |
| 18. | Refuge Area | | | |
| | <ul style="list-style-type: none"> ➤ Total area | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Location | N/A | N/A | N/A |
| 19. | Fire control room | | | |
| | <ul style="list-style-type: none"> ➤ Detector system panel | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Flow Switch Panel | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ PA System Panel | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Batter backup | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | N/A | N/A | N/A |

: Shri Guru Jambeshwar Sansthan Bhawan

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer

Name

ATUL GARG

Designation

DD/11

Signature of the Inspecting Officer

Name

D. S. Yadav

Designation

A.D.O (certified)