

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001


NO.F6/DFS/MS/GH/2012/ 1378

Dated: 17/04/12

**FIRE SAFETY CERTIFICATE**

Certified that M/s Five Star Guest House located at 3631, Netaji Subhash Marg, Daryaganj, New Delhi comprised of ground floor (Commercial use), first floor (02 guest rooms + reception+ staff room), second floor (01 guest room + owners residence) & third floor (06 guest rooms) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/09/681 dated 06-03-2009. The premises was re-inspected by the officer concerned of this department on 13-03-2012 in the presence of the Manager of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class residential (guest house) with effect from ~~17/04/12~~ for a period of 3(three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules, 2010.

Issued on 17/04/12 at New Delhi by.

  
16/4  
Chief Fire Officer  
For Director  
Delhi fire service

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1<sup>st</sup> floor, New Delhi
2. The Manager, M/s Five Star Guest House, 3631, Netaji Subhash Marg, Daryaganj, New Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfdelhi.gov.in](http://www.dfdelhi.gov.in)

Old case

**INSPECTION REPORT**

1. Name & address of the building : Five Star Guest House, 3631, Netaji Subhash Marg, Darya Ganj, New Delhi.
2. Type of Occupancy : Lodging House.
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. FB/DPS/MS/GH/09/681 Dated: 6/3/2009
5. Fire Safety directives letter No : -
6. Date of inspection : 13/03/2012
7. Name of the Inspecting Officers : M.K. Chattopadhyay, ADO (HO)
8. Name and designation of officers from the building side : Tahir, Manager
9. Year of Construction : 1980
10. Applicant's letter No. : 8016/ Addl. C.P (HC(H)) Dated 9/2/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	-	Netaji Subhash Marg	MR
	• Gate width	-	Directly accessible from the road	MR
	• Width of internal road	-	-	-
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	-	01	MR being old case.
	• Basements	-	-	-
	b. Width of staircases			
	• Upper Floors	-	1.13 mt	MR being old case.
	• Basements	-	-	-
	c. Protection of exits			
	• Fire check door	Not required	-	-
	• Pressurization	Not required	-	-
	e. No. of continuous staircases to terrace	-	01	MR
	g. Width of Corridor	-	1.0 mt	MR
	h. Door Size	-	0.92 mt	MR
		-	-	-
3	<b>Compartmentation.</b>	Not required being old case	-	-

GF - Commercial  
 FF - 02 G. rooms + reception + staff room  
 SF - 01 G. room + owner's residence.  
 TF - 06 Guest rooms.



five star Guest House, 3631, Netaji Subhash Marg  
Darya Ganj, New Delhi.

	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			
4	<b>Smoke Management System.</b>	Not required being old case.		
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour		
		12 a/c per hour		
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers 10</li> <li>• Types water CO<sub>2</sub>, CO<sub>2</sub></li> <li>• IS marking</li> </ul>	water CO <sub>2</sub> -5	provided	MR
		CO <sub>2</sub> -5	provided	MR
		ISI marked	provided	MR
6	<b>First-Aid Hose Reels.</b>	Not required		
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>			
		30 m		
		5 mm		
7	<b>Automatic fire detection and alarming system.</b>	Not required		
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			
8	<b>MOEFA</b>	Not required	—	—
9	<b>Public Address System.</b>	Not required	—	—
10	<b>Automatic Sprinkler System.</b>	Not required		
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			
11	<b>Internal Hydrants</b>	Not required.		
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	—	—	—

g

	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>			
12	<b>Yard Hydrants.</b> Not required			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>			
13	<b>Pumping Arrangements.</b> Not required			
	<ul style="list-style-type: none"> <li>• Ground Level                             <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level                             <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
14	<b>Captive Water Storage for fire fighting.</b> Not required			
	<ul style="list-style-type: none"> <li>• Underground tank capacity                             <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>			
15	<b>Exit Signage.</b>	Required	provided	MR
16	<b>Provision of Lifts.</b> Not applicable			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> </ul>	—	—	—

*[Handwritten signature]*



Five Star Guest House, 3831, Netaji Subhash Marg,  
Darya Ganj, New Delhi.

	<ul style="list-style-type: none"> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	/		
17	Standby power supply	—	5 kVA provided	MR
18	Refuge Area.	Not required		
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	/		
19	Fire Control Room	Not required.		
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	/		
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	01 CO <sub>2</sub> type fire extinguisher provided near E/panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ~~grant~~ <sup>renew</sup> Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~ .....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name (M.K. CHATTOPADHYAY)

Designation

Designation :- Assistant Divisional Officer