

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DPS/MS/School/2012/1900

Dated 19/04/12

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr. Sec. School No. 2, Gandhi Nagar, Delhi-32, comprised of ground plus one upper floor owned/occupied by Govt. Girls Sr. Sec. School No. 2, Gandhi Nagar, Delhi-32, have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.11 and verified by the officer concerned of Fire Service on dated 01.02.12 in the presence of Mrs. Indra Wali, Incharge of the school and that the building is fit for occupancy class B' Educational Building' with effect from 19/04/12 for a period of three years, subject to conditions printed overleaf.

Issued on.....19/04/12.....at New Delhi by

Chief Fire Officer
For Director
Delhi Fire Service

[Signature]
18.4.12

To

Principal
Govt. Girls Sr. Sec. School No. 2
Gandhi Nagar, Delhi-32

Copy to:-

1. Govt. Boys Sr. Sec. School No. 2
Gandhi Nagar, Delhi-32
2. The Joint Director of Education
(Land & Estate)
Directorate of Education,
Lucknow Road, Delhi -54.

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : GOVT. GIRIS SENIOR SECONDARY SCHOOL
2. Type of Occupancy : Educational No. 2 Gandhi Nagar - 21
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Dated:
5. Fire Safety directives letter No : F-16/Estate/CC/Fire Safety/ 2011/3298 to 3398
dt 1.3.2011
6. Date of inspection : 3.6.2012
7. Name of the Inspecting Officers : ADO Sunesh Singh
8. Name and designation of officers
from the building side : Mrs Indra Wali - Incharge.
9. Year of Construction : 2011 ✓
10. Applicant's letter No. : GGSSS/G.Ngr/No 2/2011/351 dated- 4.10.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6M	6M	MR
	• Gate width	—	3.90M	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	3	3	MR
	• Upper Floors	3	3	MR
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	1.5M, 1.44M	1.5M, 1.44M	MR
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	No	—	—
	g. Width of Corridor	1.50M	1.50M	MR
	h. Door Size	1M	1M	MR

3	Compartmentation.		Provided	MR
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.	N/A		
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		
5	Fire Extinguishers	Required		
	• Total numbers	8 No	8 No	MR
	• Types		CO2 + ABC	MR
	• IS marking	ISI marked	ISI	MR
6	First-Aid Hose Reels.	N/A		
	• Total numbers on each floor			
	• Length of hose reel hose	30 m		
	• Nozzle diameter	5 mm		
7	Automatic fire detection and alarming system.	N/A		
	• Type of detectors			
	• Location of Main Panel			
	• Location of Repeater Panel			
	• Alternate source of power			
	• Hooters' Location			
8	MOEFA	N/A		
9	Public Address System.	Yes		
10	Automatic Sprinkler System.	N/A		
	• Basement			

Govt Girls Senior Secondary School
No. 2 Gandhi Nagar Delhi - 91

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	-	-	-
11	Internal Hydrants	N/A		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	-	-	-
12	Yard Hydrants.	N/A		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	-	-	-
13	Pumping Arrangements.	N/A		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
14	Captive Water Storage for fire fighting.	N/A		
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	-	-	-

Govt Girls Senior Secondary School
 No-2 Gandhi Nagar Delhi-31

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15	Exit Signage.	N/A	—	—
16	Provision of Lifts.	N/A		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
17	Standby power supply	N/A	—	
18	Refuge Area.	N/A		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
19	Fire Control Room	N/A		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Govt Girl Senior Secondary School
No - 2 Gaudhr Nagar Delhi - 31

Singh
Signature of the Inspecting Officer

Name *Suresh Singh*

Designation *ADC*

~~Signature of the Inspecting Officer~~

~~Name~~

~~Designation~~

DO (East)

forwarded for approval please.

Singh