

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**


No. F6/DAS/MS/EH/2012/1371

Dated :- 17/04/12

FIRE SAFETY CERTIFICATE

Certified that the **Gung The Palace (A Unit of YJ Exim & Restaurants Pvt. Ltd.)** located at **D-1B, Green Park, New Delhi-110016.** comprised of **Basement, Ground + 2 Upper Floor (Restaurant is being run on Ground + 2 Upper Floors only)** was granted NOC by this department vide letter No. **F6/MS/DFS/EH/2009/200** dated **22/01/09** The premises was re-inspected by the officer concerned of this department on **25/03/12** in the presence of **Mr. Anshuman Bharadwaj (G.M)** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group - D Assembly Building** with effect from 17/04/12 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 17/04/12 at New Delhi by.


16/4
Chief Fire Officer
Delhi Fire Service

Copy to:- (1) Dy. Health Officer, South Zone,
MCD, New Delhi.

(2) Gung The Palace (A Unit of YJ Exim & Restaurants Pvt. Ltd.),
D-1B, Green Park, New Delhi-110016..

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Gung The Palace (A Unit of YJ Exim & Restaurants Pvt. Ltd.),D-1B,Green Park, New Delhi-110016.
2. Type of occupancy:- Group – D Assembly Building
3. Type of case:- Renewal
4. Details of previous NOC:-No. F6/MS/DFS/EH/2009/200 dated 22/01/09
5. Fire safety directives No.- No
6. Date of inspection:- 25/03/12
7. Name of the inspecting officer:-A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. Anshuman Bharadwaj (G.M).
9. Year of construction:-
10. Applicant's letter No:-Nil dated 25/02/12 Basement,Ground + 2 upper floor. (Restaurant is being run on Ground + 2 upper floors).

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Old Case BBL	Provided at site	Remarks MR/NMR
1.	Access to Building	Required	Provided	MR
	1) Road width	Required	Approachable 10 mtr. Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	Required	2 Nos. Provided	MR
	2. Basements	Required	2 Nos. Provided	MR
	B. Width of staircase			
	1. Upper floors	Old Case	100 cms.	MR
	2. Basements	Old Case	90 cms.	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	two	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	Required	100 cms.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust provided	MR
	2) Upper floors	12 a/c per hour	Exhaust fan provided	MR

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	Required	Provided	MR

	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name:-

Name:- S.S.Kaushik

Designation :-

Designation:-Assistant Divisional officer