

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2012/ EH/1404

Dated:- 19/04/12

FIRE SAFETY CERTIFICATE

Certified that the Mc-Donald family Restaurant at F-14/15 Model Town II
Delhi located at Model Town II Delhi
comprised of Ground floor for restaurant basement for Mess for Staff occupied
by Mc-Donald was issued NOC vide this office letter
No. F-6/DFS/MS/54/09/2007 Dated: 1/4/09. The premises was re-inspected by the
officer concerned of this department on 23/2/2011 and observed that all the fire
prevention and fire safety arrangements as provided in the premises found in good working
condition. The premises have therefore, deemed complied with the requirement under Rule 33
of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class
Assembly with effect from 19/04/12 for a period of
03 years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 19/04/12 at New Delhi.


18/4
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Health officer
Civil line zone
Health dept. MS
16, Rajpur Road Delhi
2. Sh. Harish Sharma
Connaught Plaza Restaurant (P) Pvt.
13, A. Terbagh Market
New Delhi 110003

1. All the means of escape shall be kept free of all type of obstruction all the time.
 2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
 3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
 4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
 5. Basement shall be used as per NBC.
 6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Mc Donalds Family Restaurant F-14/15, Model Town, N.D.
2. Type of Occupancy : Restaurant (assembly place) G.F. Rest. ^{Department} _{Storage}
3. Type of Case : New Case / Renewal
4. Details of previous NOC : Letter No. FG/DFB/MS/EH/09/907 Dated: 1/4/09
5. Fire Safety directives letter No : -
6. Date of inspection : 23-2-2012
7. Name of the Inspecting Officers : Do Jipin Kental.
8. Name and designation of officers from the building side : Ms. Thakur
9. Year of Construction : -
10. Applicant's letter No. : C.P.R. PL / FM / NOC / 2011-12 / 0021 dt 28 Feb 2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	guide lines issued by D.F.S for Requirement Restaurant Provided at site	Remarks MR/NMR
1	Access to building		
	• Road width	4.5 mtr.	P M/R
	• Gate width	N.A	-
	• Width of internal road	N.A	-
2	Number, Width, Type & Arrangement of Exits		
	a. Number of staircases		NOC already issued
	• Upper Floors		one + one
	• Basements	Two	one + Exit for emergency
	b. Width of staircases		
	• Upper Floors		
	• Basements		
	c. Protection of exits	N.A	
	• Fire check door		
	• Pressurization		
	e. No. of continuous staircases to terrace	N.A	
	g. Width of Corridor		
	h. Door Size		

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		<i>N/A</i>	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	<i>P</i>	<i>M/R</i>
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<i>4</i> <i>DEP + CO2</i> ISI marked	<i>3 ABC + 1 CO2 45kg.</i>	<i>M/R</i>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	<i>1</i> 30 m 5 mm	<i>P</i> <i>P</i> <i>P</i>	<i>M/R</i> " "
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	<i>N/A</i>	<i>P</i>	<i>-</i>
8	MOEFA	<i>R</i>	<i>P</i>	<i>M/R</i>
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	<i>R</i>	<i>P</i>	<i>M/R</i>

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	R	P	M/R
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N.A	/	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N.A	/	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N.A	/	
			P	M/R
		450 LPM →	-	-
		180 LPM.		
		R	P	M/R
		R	P	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	N.A	/	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	R	P	M/R
15	Exit Signage.	5 no hts	P	M/R
16	Provision of Lifts.	R	P	M/R
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A		
17	Standby power supply	R	P	M/R
18	Refuge Area.	N/A		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A		
19	Fire Control Room	N/A		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A		
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	no such risk at present	—

✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....X.....

Signature of the Inspecting Officer

Name

Designation

DCFO.

[Handwritten signature]

Kental

Signature of the Inspecting Officer

Name VIN KENTAL

Designation DONW