

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No F 6 / DFS / MS / 2012 / EH / 1893

Dated 18/04/12

FIRE SAFETY CERTIFICATE

Certified that the "My Restaurant" situated at Basement + Ground floor (Basement is used for storage), located at 5136, Pahar Ganj, New Delhi was granted NOC by this department vide letter No F6/ MS / DFS / EH / 2008 / 3061 dated 07.11.2008. The premises was re-inspected by the officer concerned of this department on 11.04.2012 in the presence of Mrs. Ravinder Kaur and found that the Restaurant have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D Assembly Building of with effect from 18/04/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/04/12 at New Delhi by.


18/4
Chief Fire Officer
For Director
Delhi Fire Service
etc
mer

Copy to: -

1. The Dy. Health Officer, MCD, Sadar Pahar Ganj Zone, Delhi.
2. The Manager, My Restaurant (ground floor), Located at 5136, Pahar Ganj, New Delhi .

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECITON REPORT

1. Name & address of the building: My Restaurant, (Ground floor) 5136, Pahar Ganj, New Delhi.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : - F6/MS/DFS/EH/2008/3061 Dated 07.11.2008
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 11.04.2012
7. Name of the Inspecting Officer : DO Atul Garg
8. Name and designation of Officer
from the building side : Ravinder Kaur
9. Year of Construction : N/A
10. Applicant's letter No. : Nil Dated 04.04.2012

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	N/A	N/A	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A (situated at GF)
	• Basements	one	one	MR
	b. Width of staircases			
	• Upper floors	-	-	-
	• Basements	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A

	<ul style="list-style-type: none"> • Pressurization 	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	situated at GF
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	YES	YES	MR
	<ul style="list-style-type: none"> • Upper floors 	N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	6	YES	MR
	<ul style="list-style-type: none"> • Types 	WT,CO ₂ ,ABC	YES	MR
	<ul style="list-style-type: none"> • IS marking 	YES	YES	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers 	01	01	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	30 mm	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	YES	YES	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	YES	YES	MR
	<ul style="list-style-type: none"> • Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hose Box 	N/A	N/A	N/A

13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump 	YES	450 Lpm	MR
	➤ Head of main pump	40 m	40 m	MR
	➤ Number of main pumps	01	01	MR
	➤ Jockey pump out put	250 lpm	250 lpm	MR
	➤ Jockey pump head	40 m	40 m	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	Yes	Yes	MR
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	5000 ltr	5000 ltr	MR
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage	YES	YES	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	YES	YES	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A

my Restaurant

Old Case

20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A
-----	--	-----	-----	-----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

..... X

Signature of the Inspecting Officer

AND/on leave

Name

Designation

Signature of the Inspecting Officer

ANU GARG
DO/CC

Name

Designation