

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

No. F6/DFS/MS/GH/2012/1465

Dated: 24/04/12

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Kanishka Palace** located at 7A/1, WEA, Channa Market, Karol Bagh, New Delhi-110005 comprised of Basement, Ground Floor plus three upper floors, using basement as Hall/Storage, Ground Floor as reception, office, pantry & hall, first, second & third floor each having seven guest rooms respectively (Total Twenty one guest rooms). Above guest house was issued NOC vide this office letter No.F.6/DFS/MS/GH/2009/652 dated 04/03/2009 owned/occupied by Sh. Sant Ram have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 12.04.2012 in the presence of Sh. Balwant Singh (Manager). The building/ premises is fit for occupancy class residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....24/04/12..... at New Delhi.



CHIEF FIRE OFFICER
For DIRECTOR
DELHI FIRE SERVICE



Copy to:-

1. The Addl. Commissioner of Police (Lic.)
1st floor, P.S., Defence Colony, New Delhi.
(Re. No.14878-79/Addl. C.P./Lic.(H), Dated 19.03.2012)
2. Mr. Sant Ram(Owner)
Hotel Kanishka Palace,
7A/1, WEA, Karol Bagh,
New Delhi – 110005.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/21.

Basement, Ground plus three Upper Floor

INSPECTION REPORT

1. Name & address of the building : Hotel Kanishka Palace, 7A/1, WEA, Karol Bagh, N.D-05
2. Type of Occupancy : Residential (Guest House)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F-6/DFS/MS/GH/2009/GS2 Date 04.03.2009
5. Fire Safety directives letter No : NIA
6. Date of inspection : 12.04.2012
7. Name of Inspecting Officer : D.O H.L. Anuja & A.D.O P.S. Dahiya.
8. Name and designation of officers
From the building side : Sh. Balwant Singh (Manager)
9. Year of Construction : Before 1989
10. Applicant's letter No. : 14878-79/Addl. CP/LIC.(H) dated 19.03.12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>-</p> <p>-</p>	<p>09 mtr</p> <p>115cm</p> <p>-</p>	<p>MR</p> <p>MR</p> <p>-</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	One	One	MR
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>-do-</p> <p>Two</p>	<p>-do-</p> <p>Two</p>	<p>MR</p> <p>MR</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>-</p> <p>-</p>	<p>113cm to 125cm</p> <p>113cm, 90cm</p>	<p>MR, Being Old Case</p> <p>MR</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • pressurization 	<p>NIA</p> <p>NIA</p>	<p>-</p> <p>-</p>	<p>-</p> <p>-</p>
	d. No. of continuous staircases to terrace			
	e. Width of Corridor		One	
	f. Door Size		124cm, 130cm	MR
			80cm x 207cm	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>NIA</p> <p>NIA</p> <p>NIA</p> <p>NIA</p> <p>NIA</p>	<p>-</p> <p>Sealed</p> <p>-</p> <p>-</p> <p>-</p>	<p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>30 a/c per hour</p>	<p>Exhaust fans are provided</p> <p>Natural Ventilation</p>	<p>MR</p> <p>MR</p>

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	Two at each floor	Provided	MR
	• Types	CO ₂ , H ₂ O ₂ , A.B.C	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	D.G. Set of 25 kVA	-
	• Hooters' Location	-	-	-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	- do -	- do -	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	N/A	-	-
	• Sprinkler above false ceiling	N/A	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	-	-
	• Number of hydrants per floor	N/A	-	-
	• Hose Box	N/A	-	-
12.	Yard Hydrants			
	• Total number of hydrants	N/A	-	-
	• Hose Box	N/A	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	-	-
	➤ Head of Main pump	N/A	-	-
	➤ Number of main pumps	N/A	-	-
	➤ Jockey Pump out put	N/A	-	-
	➤ Jockey pump head	N/A	-	-
	➤ Standby Pump out put	N/A	-	-
	➤ Standby Pump Head	N/A	-	-
	➤ Auto Starting/Manual stopping	N/A	-	-

N/23

7A/1, WEA
Karol Bagh, N.D-05.


	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	-	-
		450 Lpm	450 Lpm	MR
		30 M	30 M	MR
		Required	Provided	MR
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	-	-
		N/A	-	-
		N/A	-	-
		N/A	-	-
		-	2500 Ltr	MR, Being Old Capc.
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	-	-
		N/A	-	-
		-	Provided	MR
		-	-	Old lift
		-	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	-	-
		N/A	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	-	-
		N/A	-	-
		N/A	-	-
		Required	Provided	MR
		N/A	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	-	-

N/24.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to ^{Renewal} grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The short commings raised vide letter No. F.G/DFS/MS/GH/2012/833 dated 07.03.2012 are rectify by the owner.



Signature of Inspecting Officer

Name H.L. Aneja

Designation Divisional Officer



Signature of Inspecting Officer

Name P.S. Dahiya

Designation ABAtt. Divisional Officer