

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001


No: F 6/DFS/MS/2012/ school/1595

Dated:- 02/05/12

FIRE SAFETY CERTIFICATE

Certified that the MCD Pratibha School Y-Block, Mangol Puri
Delhi comprised of Ground + one upper
floor with 11 class rooms owned/occupied by MCD
Pratibha School. complied with the fire prevention and fire
safety requirement in accordance with rule 33 of the Delhi Fire Service Rule 2010 and verified
by the officer concerned of Fire Service on 9/4/2012 in the presence of
Smt. Reeta Gupta and that the building/premises is fit for occupancy
Educational building with effect from 02/05/12 for a period of
03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 02/05/12 at New Delhi.


Chief Fire Officer
Delhi Fire Service

9/5/12

Copy to:-

1. The Principal
M.C.D. Pratibha School
Y-Block, Mangol Puri
Delhi

2. The Addl. Director Edu. (M.C.D.)
Old Hindu College Bldg.
18- Gurgaon Delhi

Note:- Guidelines overleaf may also be taken care of.

1. All the means of escape shall be kept free of all type of obstruction all the time.
 2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
 3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
 4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
 5. Basement shall be used as per NOC.
 6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : MCD Prati bha school, Y Block, Mangal Puri, Delhi
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: _____
5. Fire Safety directives letter No : F-16/estate/cc/f.safety/11/3298-3398 dt. 13/11
6. Date of inspection : 09/4/2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers from the building side : Principal - Smt. Reeta Gupta.
9. Year of Construction : 2008 (Ground +1)
10. Applicant's letter No. : Nil dated 29-2-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular Direct of Edm Requirement 1/3/2011</u>	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>6 m</u>	<u>M/R</u>
	• Gate width	<u>-do-</u>	<u>3.80 m</u>	<u>M/R</u>
	• Width of internal road	<u>-do-</u>	<u>NR</u>	<u>M/R</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>2</u>	<u>2</u>	<u>M/R</u>
	• Upper Floors	<u>2</u>	<u>2</u>	<u>M/R</u>
	• Basements	<u>Nil</u>	<u>Nil</u>	<u>-</u>
	b. Width of staircases	<u>1.5 m</u>	<u>1.7 m & 1.3 m</u>	<u>M/R</u>
	• Upper Floors	<u>-do-</u>	<u>-do-</u>	<u>M/R</u>
	• Basements	<u>Nil</u>	<u>Nil</u>	<u>-</u>
	c. Protection of exits			
	• Fire check door		<u>NR</u>	
	• Pressurization			
	e. No. of continuous staircases to terrace	<u>-</u>	<u>Nil</u>	
	g. Width of Corridor	<u>-</u>	<u>2.30 m</u>	<u>M/R</u>
	h. Door Size	<u>1 m</u>	<u>1.10 m</u>	<u>M/R</u>

Med. possible during
 Y. Blom Merged

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			NR	
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		NR	
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	300 m ² covered area for one CO2 (2.5 kg) or ABC ISI marked	OU ABC yes	MIR MIR MIR	
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm		NIR	
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			NIR	
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement 			NIR	

Noted for at the same
 7 - Block Major fire

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			N/R
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.			N/R
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.			N/R
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
14	Captive Water Storage for fire fighting.			N/R
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 			

