

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001

No: F.6/DFS/MS/2012/ *school/1524*

Dated: *27/04/12*

FIRE SAFETY CERTIFICATE

Certified that the – **M.C. Primary Girl School- Ist & IInd shift**, Village Dasghara, New Delhi-110012 Comprised of - ground plus one upper floor, owned/occupied by Director of Education M.C.D has complied with the fire prevention and fire safety requirements in accordance with the Director of Education letter No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of fire Service on 04.04.12 in the presence of - Smt. Urmila Principal and that the building/premises is fit for occupancy class – group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on*27/04/12*.....at New Delhi.



Chief Fire Officer
Delhi Fire Service

O/c
men

Copy to:

1. The Principal,
M.C. Primary Girl School-Ist & IInd shift,
Village Dasghara-I-II,
New Delhi-110012.
2. The Director of Education
MCD Nigam Bhawan (Old Hindu Collage Bldg)
Kashmere Gate, Delhi.
3. Divisional Officer (South West)
Shanker Road Fire Station, New Delhi

G+I

INSPECTION REPORT

1. Name & address of the building : M.C. Primary School, Dasghara - I 2nd Shift.
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. N/C Dated: _____
5. Fire Safety directives letter No : N/C
6. Date of inspection : 03.03.12.
7. Name of the Inspecting Officers : D.O. H.C. ANESA
8. Name and designation of officers from the building side : Mrs Umida. Principal.
9. Year of Construction : —
10. Applicant's letter No. : N/C - dt 8/11/12 19/12/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R	6mtr	MR
	• Gate width	R	3.70mtr	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases	(R) 2 Nos	2 Nos	MR
	• Upper Floors	—	—	MR
	• Basements	N/C	—	—
b.	Width of staircases	R	152cms & 142cms	MR
	• Upper Floors	—	—	—
	• Basements	N/C	—	—
c.	Protection of exits	MR	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
e.	No. of continuous staircases to terrace	R	2 Nos	MR
g.	Width of Corridor	R	3.13mtr	—
h.	Door Size	R	1.13 mtr	—

3	Compartmentation.						
	• Fire check door	NR					
	• Sealing of electrical shafts						
	• Fire Rating of shaft door						
	• Water Curtain						
	• Fire Dampers						
4	Smoke Management System.						
	• Basements	NR					
	• Upper floors	30 a/c per hour 12 a/c per hour					
5	Fire Extinguishers						
	• Total numbers	R		P			MR
	• Types			S Nos			MR
	• IS marking	ISI marked		ABC type			MR
				YES.			MR
6	First-Aid Hose Reels.						
	• Total numbers on each floor	NR					
	• Length of hose reel hose	30 m					
	• Nozzle diameter	5 mm					
7	Automatic fire detection and alarming system.						
	• Type of detectors	NR					
	• Location of Main Panel						
	• Location of Repeater Panel						
	• Alternate source of power						
	• Hooters' Location						
8	MOEFA						
9	Public Address System.	NR					
10	Automatic Sprinkler System.						
	• Basement	NR					
		ABC					

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 				
11	Internal Hydrants	NR			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 				
12	Yard Hydrants.	NR			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 				
13	Pumping Arrangements.	NR			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 				
14	Captive Water Storage for fire fighting.	NR			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 				

1	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	—	—	—
15	Exit Signage.	NR	—	—
16	Provision of Lifts.	NR	—	—
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	NR	—	—
18	Refuge Area.	NR	—	—
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room	NR	—	—
	• Detector System Panel	—	—	—
	• Fldw Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	NR	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... Nil.....

15

[Handwritten Signature]

Signature of the Inspecting Officer

Name H. L. ANEJA

Designation Dir. Officer

Signature of the Inspecting Officer

Name

Designation