

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DPS/MS/Banquet/2012/1454

Dated : 23/04/12

FIRE SAFETY CERTIFICATE

Certified that the banquet in the name & style M/S S.K Ceremony & Banquet Hall, Aggarwal Fun City Mall, Plot No.29-31, CBD Shahdara, Delhi at second floor of Aggarwal Fun City Mall, owned/occupied by M/S S.K Ceremony & Banquet Hall have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 13.04.12 in the presence of Sh. Gorav that the building is fit for occupancy Group -D (Assembly building) with effect from 23/04/12 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....23/04/12.....at New Delhi by



Chief Fire Officer
For Director
Delhi Fire Service

DL
RSD
20.4.12

Dy. Health Officer
M.C.D, Shahdara
South Zone, Delhi.

Copy to:-

M/S S.K Ceremony & Banquet Hall,
Aggarwal Fun City Mall, Plot No. 29-31,
CBD Shahdara, Delhi.

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : S.K .Ceremony and Banquet Hall, at 2nd Floor, Aggarwal Fun City Mall , Plot No. 29-31, CBD Shahdara, Delhi
2. Type of Occupancy : Assembly
3. Type of Case : New
4. Details of Previous NOC : F.6/DFS/MS/2008/730 dated 11.03.08 for Funcity mall.
5. Fire Safety directives No : F.6/DFS/MS/2011/2166 dated 06.09.11
6. Date of Inspection : 13.04.12
7. Name of the Inspecting Officer : ADO Suresh Singh
8. Name of the designation of Officer
From the building side : Sh.Gorav
9. Year of Construction : 2005
10. Applicant's letter No : 18.01.12

	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	12 Mtrs	26 Mtrs. ✓	MR
	• Gate width	4.5 Mtrs.	5 Mtrs. ✓	MR
	• Width of internal road	-----	-----	-----
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	03 Nos.	03 Nos. ✓	MR
	• Upper Floor	03 Nos	03 Nos. ✓	MR
	• Basement	03 Nos	03 Nos. ✓	MR
	B. Width of Staircases	1.5 M	1.5 M ✓	MR
	• Upper Floor	1.5 M	1.5 M ✓	MR
	• Basement	1.5 M	1.5 M ✓	MR
	c. Protection of exits			
	• Fire check door	Required	Provided ✓	MR
	• Pressurization	Required	Provided ✓	MR
	e. No. of continuous staircases to terrace	2 Nos.	2 Nos. ✓	MR
	g. Width of Corridor	2.5 Mtrs	2.5 Mtrs ✓	MR
	h. Door Size	2.0 Mtr.	1no. of 3.5 Mtr.& 2 nos. of 2.5 Mtr. ✓	MR
3	Compartmentation.			
	• Fire check door	Required	Provided ✓	MR
	• Sealing of electrical shafts	Required	Sealed ✓	MR
	• Fire rating of shaft door	2 hrs.	2 hrs. ✓	MR
	• Water curtain	-----	-----	-----
	• Fire Dampers	Required	Provided ✓	MR
4	Smoke Management System.			
	• Basement	30a/c per hour	provided ✓	MR
	• Upper floor	12 a/c per hour	--do-- ✓	MR
5.	Fire Extinguisher			
	• Total numbers	06 no.	06 No. ✓	MR
	• types	ABC & Co2	ABC & Co2 ✓	MR

	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	• Total numbers of each floor	4 no.	Provided ✓	MR
	• Length of hose reel hose	30 m	Provided ✓	MR
	• Nozzle diameter	5 mm	Provided ✓	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Heat & smoke	Provided ✓	MR
	• Location of main panel	Control Room	1 st basement	MR
	• Location of repeater panel	Security Room	Provided ✓	MR
	• Alternate source of power	Battery & DG Set	Provided ✓	MR
	• Hooters's location	Different Location	Different Location ✓	MR
8	MOEFA	Required	Provided ✓	MR
9	Public address System.	Required	provided ✓	MR
10	Automatic Sprinkler System.	Required	Provided	MR
	• basement	Required	Provided in entire basement	MR
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	Required	Provided ✓	MR
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm ✓	MR
	• Number of hydrants per floor	04 nos.	04 nos. ✓	MR
	• Hose Box	04 nos.	04 nos. ✓	MR
12	Yard Hydrants.			
	• Total number of hydrants	3 nos.	3 nos. ✓	MR
	• Hose Box	3 nos.	3 nos. ✓	MR
13	Pumping Arrangements.			
	• Ground Level	Required	Provided ✓	MR
	➤ Discharge of main Pump	2280 LPM	2280 LPM ✓	MR
	➤ Head of Main Pump	60 Mtrs.	60 mtrs ✓	MR
	➤ Number of main pumps	1 nos.	1 nos. ✓	MR
	➤ Jockey pump out put	450 LPM	450 LPM ✓	MR
	➤ Jockey pump head	60 Mtrs.	60 mtrs. ✓	MR
	➤ Standby pump out put	2280 LPM	2280 LPM ✓	MR
	➤ Standby pump Head	60 Mtrs	60 Mtrs. ✓	MR
	➤ Auto Starting /Manual stopping	Auto	Provided ✓	MR
	➤ Pump House Access	Required	Provided ✓	MR
	• Terrace Level			
	➤ Discharge of pump
	➤ Head of the Pump
	➤ Power supply
	➤ Auto Starting of pump

(M/s. SK Ceremony & Banquets)

2

14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	2,00,000 Ltrs.	2,00,000 Ltrs.	MR ✓
	➤ Draw-off connection	Required	Provided	MR ✓
	➤ Fire service inlet	Required	Provided	MR ✓
	➤ Access to tank	Required	Provided	MR ✓
	• Overhead Tank capacity	25000 Ltrs.	25000 Ltrs.	MR ✓
15	Exit Signage.	Required	Provided	MR ✓
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	provided	MR ✓
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	Required	Provided	MR ✓
	• Firemen's grounding switch	Required	Provided	MR ✓
	• Lift Signage	Required	Provided	MR ✓
17	Standby power supply	Required	1000 KVA	MR ✓
18	Refuge Area.	-----	-----	-----
	• Total area	-----	-----	-----
	• Location	-----	-----	-----
19	Fire Control Room			
	• Detector system panel	Required	Provided	MR ✓
	• Flow switch panel	Required	----do----	MR ✓
	• PA system panel	Required	----do----	MR ✓
	• Batter backup	Required	----do----	MR ✓
	• Building Floor Plans	Required	----do---	MR ✓
20	Special Fire Protection systems for protection of special Risks, if any:	-----	-----	-----

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Singh

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name *Suresh Singh*

Name

Designation *ASO*

Designation

(NOTE) Forwarded for approval pl.

Dy. CFO

Khajur
13/11/12