

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/2012/1611

Dated: 03/05/2012

FIRE SAFETY CERTIFICATE

Certified that the **D.K. Plaza Restaurant** located at A-12 Vishal Enclave Rajouri Garden, New Delhi., comprised of basement, ground floor & two upper floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2006/3341 dated 05-12-2008. The premises was re-inspected by the officers concerned of this department on **20/04/2012** in the presence of **Mr. Kulmohan** of the Restaurant and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class D (Assembly)** occupancy with effect from 03/05/12 for a period of three years subject to conditions printed overleaf.

Issued on.....03/05/12.....at New Delhi by


Chief Fire Officer
Delhi Fire Service

etc
Men

Copy to:

1. Mr. Kulmohan
D.K. Plaza Restaurant
A-12 Vishal Enclave Rajouri Garden, New Delhi
2. Dy. Health Officer
Municipal Corporation of Delhi, (West Zone)
Rajouri Garden, New Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. D-481/HD/WZ dated 03-04-2012 received from DHO (WZ), regarding renewal of NOC in r/o D.K. Plaza Restaurant located at A-12 Vishal Enclave Rajouri Garden, New Delhi. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa:

1. Name & address of the building : **D.K. Plaza Restaurant** located at A-12 Vishal Enclave Rajouri Garden, New Delhi.
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2006/3341 dated 05-12-2008
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 20/04/2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary
8. Name and designation of officers
 From the building side : Mr. Kulmohan
 Year of Construction :
9. Applicant's letter No. : D-481/HD/WZ dated 03-04-2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06 mtrs	20 mtr	M/R
	• Gate width	5 mtr	Abutting 20 mtr wide road	M/R
	• Width of internal road	N.R.	N.R.	N.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2	2	M.R
	• Upper Floors	2	2	M.R
	• Basement	2	2	M.R.

b. Width of staircases	<ul style="list-style-type: none"> Upper Floors 	Not applicable being renewal case	75 cm approx.	M.R.
		<ul style="list-style-type: none"> Basement 	Not applicable being renewal case	75 cm approx.
	c. Protection of exits	Required	Provided	M.R.
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Pressurization 	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	2	2	M.R.
	e. Width of Corridor	Halls only	Halls only	M.R.
	f. Door size	2 mtr	Provided	M.R.
3.	Compartmentation.			
<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required	Provided	M.R.	
	N/A	N/A	N.A.	
	N/A	N.R.	N.A.	
	N/R	N/R	N.R.	
	N/A	N/R	N.R.	
4.	Smoke Management System.			
<ul style="list-style-type: none"> Basements Upper floors 	Required	Provided	M.R.	
	Required	Provided	M.R.	
5.	Fire Extinguishers			
<ul style="list-style-type: none"> Total numbers Types IS marking 	12	25	M.R.	
	ABC & CO ₂	provided	M.R.	
		provided	M.R.	

6.	First-Aid Hose Rees.			
	• Total numbers on each floor	1	Provided	M.R ✓
	• Length of hose reel hose	30 m required	provided	M.R ✓
	• Nozzle diameter	5 mm required	provided	M.R ✓
7.	Automatic fire detection and alarming system.			
	• Type of detectors	N.A.	N.A.	M.R renewal case ✓
	• Location of Main Panel	N.A.	N.A.	M.R renewal case ✓
	• Location of Repeater Panel	N.A.	N.A.	M.R renewal case ✓
	• Alternate source of power	N.A.	N.A.	M.R renewal case ✓
	• Hooter's Location	N.A.	N.A.	M.R renewal case ✓
8.	MOEFA	Required	Provided	M.R ✓
9.	Public Address System	N.R.	N.R.	N.R ✓
10.	Automatic Sprinkler system			
	• Basement	Required	Provided	M.R ✓
	• Upper Floor	Required	Provided	M.R ✓
	• Sprinkler above false ceiling	Required	Provided	M.R ✓
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	provided	M.R ✓
	• Number of hydrants per floor	1	Provided	M.R ✓
	• Hose Box	1	Provided	M.R ✓

12.	Yard Hydrants.			
	• Total number of hydrants	N/R	N/R	N.R. ✓
	• Hose Box	N/R	N/R	N.R. ✓
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N/R	N/R	N/R ✓
	➤ Head of Main pump	N/R	N/R	N/R ✓
	➤ Number of main pumps	N/R	N/R	N/R ✓
	➤ Jockey Pump out put	N/R	N/R	N/R ✓
	➤ Jockey pump head	N/R	N/R	N/R ✓
	➤ Standby pump out put	N/R	N/R	N/R ✓
	➤ Standby pump Head	N/R	N/R	N/R ✓
	➤ Auto Starting/Manual stopping	N/R	N/R	N/R ✓
	➤ Pump Hose Access	Required	Provided	M.R. ✓
	Terrace level			
	➤ Discharge of pump	450 LPM	Provided	M.R. ✓
	➤ Head of the pump	70 mtr	Provided	M.R. ✓
	➤ Power supply	Required	Provided	M.R. ✓
	➤ Auto Starting of pump	Required	Provided	M.R. ✓
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	N/R	N/R	N.R. ✓

	➤ Draw -off connection	N/R	N/R	N.R.
	➤ Fire service inlet	N/R	N/R	N.R.
	➤ Access to tank	N/R	N/R	N.R.
	➤ Overhead Tank Capacity	10,000 ltr	15,000	M.R
15	Exit Signage.	Required	Provided	M.R
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N.R. Renewal Case
	• Pressurization of Lift lobby	N/A	N/A	N.R. Renewal Case
	• Communication In lift Car	N/A	N/A	N.R. Renewal Case
	• Fireman's Grounding Switch	N/A	N/A	N.R. Renewal Case
	• Lift Signage	Required	Provided	M.R.
17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area	N.R.	N.R	N.R
	➤ Total Area	N.R.	N.R.	N.R
	➤ Location	N.R.	N.R.	N.R
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	N.R
	➤ Flow Switch Panel	N.R.	N.R.	N.R
	➤ PA system Panel	N.R.	N.R.	N.R
		N.R.	N.R.	N.R

	<ul style="list-style-type: none"> ➤ Batter backup ➤ Building Floor plans 	N.R.	N.R.	N.R.
20.	<p>Special Fire Protection Systems for</p> <p>Protection of special Risks, if any:</p>	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

SUNIL CHAWDHARY

Name

Designation

D.O.

Designation