

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/EH/2012/1613

Dated: 03/05/2012

FIRE SAFETY CERTIFICATE

Certified that the **KITCHEN & LOUNGE** (A unit of Kapil International Pvt. Ltd.) located at 3<sup>rd</sup> floor, TDI Mall, Rajouri Garden, New Delhi., comprised of lower basement, upper basement & ground + four floors was granted NOC by this department vide letter No. **F6/DFS/MS/EH/2006/3209** dated **30/10/2006**. The premises was re-inspected by the officers concerned of this department on **27/04/2012** in the presence of **Sh. Ashish Kumar (Director)** of the Restaurant and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class -D (Assembly)** occupancy with effect from 03/05/12 for a period of three years subject to conditions printed overleaf.

Issued on 03/05/12 at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service  
of  
Mw

Copy to:  
**Sh. Ashish Kumar (Director)**  
KITCHEN & LOUNGE  
(A unit of Kapil International Pvt. Ltd)  
3<sup>rd</sup> floor, TDI Mall, Rajouri Garden, New Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified by the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

May Kindly peruse letter no. nil dated 16-04-2012 received from Sh. Ashish Kumar (Director) regarding issue of NOC in favor of their KITCHEN & LOUNGE (A unit of Kapil International Pvt. Ltd.) located at 3<sup>rd</sup> floor, TDI Mall, Rajouri Garden, New Delhi. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : KITCHEN & LOUNGE (A unit of Kapil International Pvt. Ltd.) located at 3<sup>rd</sup> floor, TDI Mall, Rajouri Garden, New Delhi.
2. Type of Occupancy : Class -D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2006/3209 dated 30/10/2006 (For Restaurant)
5. Fire Safety directives letter No. : F6/MS/DFS/BP/2004/307 dated 06/02/2004 (for Mall)
6. Date of inspection : 27.04.2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chawdhary
8. Name and designation of officers  
From the building side : Sh. Ashish Kuamr Sharma
9. Year of Construction :
10. Applicant's letter No. : nil dated 16-04-2012

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	09mtrs	30 mtr	M/R ✓
	• Gate width	6 mtr	6 mtr	M/R ✓
	• Width of internal road	12 mtr, 9 mtr & 7.5 mtr	6 mtr	M/R ✓
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	8	Provided	In Mall / M.R. ✓
	• Upper Floors	Three	Provided	“ ” M.R. ✓

	<ul style="list-style-type: none"> <li>Basement</li> </ul>	8+2 ramps	Provided	“ ” M.R
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	1.5 mtr & 1.25 mtrs	Provided	M.R.
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	1.5 mtr & 1.25 mtrs	Provided	M.R
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	Required	Provided	M.R
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	Required	Provided	M.R
	d. No. of continuous staircases to terrace	5	provided	M.R
	e. Width of Corridor	2	2.5	M.R
	f. Door size	2 mtrs for the Restaurant	Provided	Width of the restaurant Gate M.R.
3.	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	Required	Provided	In mall, M.R
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	Required	Provided	“ “ M.R
	<ul style="list-style-type: none"> <li>Fire Rating of shaft door</li> </ul>	1 hrs	Provided	“ “ M.R
	<ul style="list-style-type: none"> <li>Water Curtain</li> </ul>	N.R.	N.A.	“ “ N.R
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	Required	Provided	“ “ M.R
4.	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	Required in the Kitchen	Provided in the Kitchen	In the Restaurant M.R
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	Required	Provided	“ “ M.R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	4, for the restaurant	8 provided	In the Restaurant, M.R

	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC & CO <sub>2</sub>	provided	M.R.
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	required	provided	M.R.
<b>6.</b>	<b>First-Aid Hose Rees.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	four	three	In Mall/M.R.
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	required	“ “ M.R.
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	provided	“ “ M.R.
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Smoke & Heat	Provided	“ “ M.R.
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Ground floor	Provided	“ “ M.R.
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	Ground floor	Provided	“ “ M.R.
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	“ “ M.R.
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	All over building	Provided	“ “ M.R.
<b>8.</b>	<b>MOEFA</b>	Required	Provided	“ “ M.R.
<b>9.</b>	<b>Public Address System.</b>	Required	Provided	In the Mall M.R.
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	“ “ M.R.
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required	Provided	“ “ M.R.
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	“ “ M.R.
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	150 mm	Provided	“ “ M.R.

	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	4	4	“ “ M.R.
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	4	4	“ “ M.R.
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	4	4	“ “ M.R.
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	4	4	“ “ M.R.
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	4500 LPM	Provided	“ “ M.R.
	➤ Head of Main pump	65 mtr	Provided	“ “ M.R.
	➤ Number of main pumps	2	Provided	“ “ M.R.
	➤ Jockey Pump out put	180 LPM	Provided	“ “ M.R.
	➤ Jockey pump head	65 mtr	Provided	“ “ M.R.
	➤ Standby pump out put	4500 LPM	Provided	“ “ M.R.
	➤ Standby pump Head	65 mtr	Provided	“ “ M.R.
	➤ Auto Starting/Manual stopping	Required	Provided	“ “ M.R.
	➤ Pump Hose Access	Required	Provided	“ “ M.R.
	<b>Terrace level</b>			
	➤ Discharge of pump	900 LPM	Provided	“ “ M.R.
	➤ Head of the pump	65 mtr	Provided	“ “ M.R.
	➤ Power supply	Required	Provided	“ “ M.R.

	➤ Auto Starting of pump	Required	Provided	“ “ M.R
<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	One lakh	provided	“ “ M.R
	➤ Draw -off connection	Required	Provided	“ “ M.R
	➤ Fire service inlet	Required	Provided	“ “ M.R
	➤ Access to tank	Required	Provided	“ “ M.R
	➤ Overhead Tank Capacity	Required 30,000 ltrs	Provided	“ “ M.R
<b>15</b>	<b>Exit Signage.</b>	Required in the restaurant	Provided	In the Restaurant, M.R.
<b>16.</b>	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	Required	Provided	In the Mall M.R
	• Pressurization of Lift lobby	Required	Provided	“ “ M.R
	• Communication In lift Car	Required	Provided	“ “ M.R
	• Fireman's Grounding Switch	Required	Provided	“ “ M.R
	• Lift Signage	Required	Provided	“ “ M.R
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	“ “ M.R
<b>18.</b>	<b>Refuge Area</b>			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
<b>19.</b>	<b>Fire Control Room</b>			

	➤ Detector System Panel	Required	Provided	In Mall/M.R
	➤ Flow Switch Panel	Required	Provided	“ “ M.R
	➤ PA system Panel	Required	Provided	“ “ M.R
	➤ Batter backup	Required	Provided	“ “ M.R
	➤ Building Floor plans	Required	Provided	“ “ M.R
20.	Special Fire Protection Systems for  Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

SUNIL CHANDAN

Name

Designation

D.O - where is Add  
N

Designation