

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.


No. F.6/DFS/MS/school/2012/1625

Dated: 04/05/12

FIRE SAFETY CERTIFICATE

Certified that the **MDH International School** (An Institute of Mahashay Chuni Lal Charitable Trust) located at Sec-6, Pocket-2, Plot No-3, Dwarka, New Delhi-110075 comprised of ground floor plus three upper floors, having total 43 rooms (Including Class Rooms, Office, Sci. Lab, Comp. Lab, Staff Room, Examination Room, Store & Library etc.). The school was issued NOC vide this office letter No.F.6/MS/DFS/2003/1537 dated 09.07.2003 owned/ occupied by the Management of above said school have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 28.04.2012 in the presence of School Principal Smt. Nandini Bidalia. The building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....04/05/12..... at New Delhi.


CHIEF FIRE OFFICER
For DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Principal,
MDH International School,
Sec-6, Pocket-2, Plot No-3,
Dwarka, New Delhi-110075.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110 054

92
Rsd
4/5/12

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on **www.dfs.delhigovt.nic.in**

Ground plus Three upper floors

INSPECTION REPORT

1. Name & address of the building : MDH International School, Sec-6, Pkt-2, Plot No-3, Dwarka, N.D-75.
2. Type of Occupancy : Educational (School)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.6/MS/DFS/2003/1537 Date 09.07.03
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2002/1659 dated 19.09.2002
6. Date of inspection : 28.04.2012
7. Name of Inspecting Officer : A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Smt. Mandini Bidalia (Principal)
9. Year of Construction : Before 2002
10. Applicant's letter No. : Nil dated 28.02.12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	• Road width	Accessible	09mtr	MR
	• Gate width	-	4.50mtr	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Two	Two	MR
	• Upper Floors	-do-	-do-	MR
	• Basements	-	-	No Basement
	b. Width of staircases			
	• Upper Floor	150cms	150cms, 156cms	MR
	• Basements	-	-	No Basement
	c. Protection of exits			
	• Fire check door	N/A	-	-
	• pressurization	N/A	-	-
	d. No. of continuous staircases to terrace	-	Two	-
	e. Width of Corridor	-	180cms	-
	f. Door Size	-	130cms x 202cms	-
3.	Compartmentation			
	• Fire check door	N/A	-	-
	• Sealing of electrical shafts	N/A	Sealed	-
	• Fire Rating of shaft door	N/A	-	-
	• Water Curtain	N/A	-	-
	• Fire Dampers	N/A	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	-	No Basement
	• Upper floors		Natural Ventilation	MR

		12 a/c per hour		
5.	Fire Extinguishers			
	• Total numbers	four at each floor	Provided	MR
	• Types	A.B.C, Co ₂	- do - /	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do - /	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	D.G. Set of 8 kva /	-
	• Hooters' Location	-	-	-
8.	MOEFA	N/A	-	-
9.	Public Address System	N/A	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	N/A	-	-
	• Sprinkler above false ceiling	N/A	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	100 m.m /	MR
	• Number of hydrants per floor	-	One	MR
	• Hose Box	-	One	MR
12.	Yard Hydrants			
	• Total number of hydrants	-	One	MR
	• Hose Box	-	One	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	-	-
	➤ Head of Main pump	N/A	-	-
	➤ Number of main pumps	N/A	-	-
	➤ Jockey Pump out put	N/A	-	-
	➤ Jockey pump head	N/A	-	-
	➤ Standby Pump out put	N/A	-	-
	➤ Standby Pump Head	N/A	-	-
	➤ Auto Starting/Manual stopping	N/A	-	-

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	-	-
		900 LPM	900 LPM	MR
		30m Required	30m Provided	MR
		-	-	MR
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50000 ltr	50000 ltr	MR
		-	-	-
		-	-	-
		-	Provided	MR
		10000 ltr	10000 ltr	MR
15.	Exit Signage.	-	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	No Lift
		-	-	-do-
		-	-	-do-
		-	-	-do-
		-	-	-do-
17.	Standby power supply	-	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	-	-
		N/A	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	-	-
		N/A	-	-
		N/A	-	-
		-	Provided	MR
		N/A	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to ^{Renewal} grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer

Do (SW)

Submitted, please
Harej
1/11/2

Signature of Inspecting Officer

Name

Designation