

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/EH/2012/1610

Dated: 03/05/2012

FIRE SAFETY CERTIFICATE

Certified that the **PULSE RESTAURANT** (A Unit of Nanak Food) located at first floor A-5, Vishal Enclave, Rajouri Garden, New Delhi-110027., comprised of ground plus two floors & terrace floor was granted NOC by this department vide letter No. F6/DFS/MS/EH/2009/743 dated 17/03/2009. The premises was re-inspected by the officers concerned of this department on 27/04/2012 in the presence of **Sh. Anudeep Narang** of the Restaurant and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class -D (Assembly)** occupancy with effect from 03/05/12 for a period of three years subject to conditions printed overleaf.

Issued on 03/05/12 at New Delhi by


Chief Fire Officer
Delhi Fire Service

o/c
nw

Copy to:

1. Sh. Anudeep Narang
PULSE RESTAURANT
(A Unit of Nanak Food), first floor A-5, Vishal Enclave, Rajouri Garden, New Delhi-110027.
2. Special Secretary (Tourism)
Tourism Department
GNCT, Vikas Bhawan-II, 2nd floor, C-Wing, Upper Bela Road, Near Metcalf House, Delhi-110054

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified by the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. F.22/11/Tsm/04/560 dated 20-01-2012 received from Sh. Devinder Singh Special Secretary (Tourism) Tourism Department GNCT. regarding renewal of NOC in r/o PULSE RESTAURANT (A Unit of Nanak Food) located at first floor A-5, Vishal Enclave, Rajouri Garden, New Delhi-110027. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa:

1. Name & address of the building : **PULSE RESTAURANT** (A Unit of Nanak Food) located at first floor A-5, Vishal Enclave, Rajouri Garden, New Delhi-110027.
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2005/⁷⁴³~~1045~~ dated 19/05/2005 2009 *DM*
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 27/04/2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary
8. Name and designation of officers
From the building side : Sh. Anudeep Narang
Year of Construction :
9. Applicant's letter No. : nil dated 01-02-2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 mtrs	30 mtr	M/R ✓
	• Gate width	4.5 mtr	Abutting main road	M/R ✓
	• Width of internal road	N.R.	N.R.	N.R. ✓
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2	2	M.R ✓
	• Upper Floors	2	2	M.R ✓

	<ul style="list-style-type: none"> Basement 	N.A.	N.A.	Not applicable
b.	Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	renewal case 75 cm	renewal case 75 cm	M.R.
	<ul style="list-style-type: none"> Basement 	N.A.	N.A.	Not applicable
c.	Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	N/R	N/R	N.R.
	<ul style="list-style-type: none"> Pressurization 	N/R	N/R	N.R.
d.	No. of continuous staircases to terrace	2	2	M.R
e.	Width of Corridor	Halls only	Halls only	M.R
f.	Door size	2 mtr	Provided	M.R.
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	N/R	N/R	N.R.
	<ul style="list-style-type: none"> Sealing of electrical shafts 	N/A	N/A	N.R.
	<ul style="list-style-type: none"> Fire Rating of shaft door 	N/A	N/A	N.R.
	<ul style="list-style-type: none"> Water Curtain 	N/R	N/R	N.R.
	<ul style="list-style-type: none"> Fire Dampers 	N/A	N/A	N.R.
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	N/R	N/R	N.R
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	M.R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	8	12	M.R

	<ul style="list-style-type: none"> Types 	ABC & CO ₂	provided	M.R
	<ul style="list-style-type: none"> IS marking 	ISI marks	provided	M.R
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	1	Provided	M.R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	provided	M.R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	provided	M.R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N.R.	N.R.	N.R
	<ul style="list-style-type: none"> Location of Main Panel 	N.R.	N.R.	N.R
	<ul style="list-style-type: none"> Location of Repeater Panel 	N.R.	N.R.	N.R
	<ul style="list-style-type: none"> Alternate source of power 	N.R.	N.R.	N.R
	<ul style="list-style-type: none"> Hooter's Location 	N.R.	N.R.	N.R
8.	MOEFA	N.R.	N.R.	N.R
9.	Public Address System	Required	Provided	M.R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N.A.
	<ul style="list-style-type: none"> Upper Floor 	required	Provided	M.R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	required	Provided	M.R
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	provided	M.R

	<ul style="list-style-type: none"> Number of hydrants per floor 	1	Provided	M.R ✓
	<ul style="list-style-type: none"> Hose Box 	1	Provided	M.R ✓
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> Hose Box 	N/R	N/R	N.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N/R	N/R	N.R.
	➤ Head of Main pump	N/R	N/R	N.R.
	➤ Number of main pumps	N/R	N/R	N.R.
	➤ Jockey Pump out put	180 LPM	Provided	M.R
	➤ Jockey pump head	40 mtr	Provided	M.R
	➤ Standby pump out put	N/R	N/R	N.R.
	➤ Standby pump Head	N/R	N/R	N.R.
	➤ Auto Starting/Manual stopping	Required	Provided	M.R
	➤ Pump Hose Access	Required	Provided	M.R
	Terrace level			
	➤ Discharge of pump	Renewal case 450 LPM	Provided	M.R
	➤ Head of the pump	50 mtr	Provided	M.R

	➤ Power supply	Required	Provided	M.R. ✓
	➤ Auto Starting of pump	Required	Provided	M.R. ✓
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	N/R	N/R	N.R. ✓
	➤ Draw -off connection	N/R	N/R	N.R. ✓
	➤ Fire service inlet	N/R	N/R	N.R. ✓
	➤ Access to tank	N/R	N/R	N.R. ✓
	➤ Overhead Tank Capacity	5, 000 ltr	Provided	M.R. ✓
15	Exit Signage.	Required	Provided	M.R. ✓
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	Not applicable ✓
	• Pressurization of Lift lobby	N/A	N/A	Not applicable ✓
	• Communication In lift Car	N/A	N/A	Not applicable ✓
	• Fireman's Grounding Switch	N/A	N/A	Not applicable ✓
	• Lift Signage	N/A	N/A	Not applicable ✓
17.	Standby power supply	Required	Provided	M.R. ✓
18.	Refuge Area	N.R.	N.R.	N.R. ✓
	➤ Total Area	N.R.	N.R.	N.R. ✓
	➤ Location	N.R.	N.R.	N.R. ✓
19.	Fire Control Room			

	➤ Detector System Panel	N.R.	N.R.	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

SUNIL CHAUDHARY

Name

Designation

D.O

Speaker

Designation