

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2012/ 1650

Dated:- 07/05/12

FIRE SAFETY CERTIFICATE

Certified that the Sankalp by Jan Kalyan Siksha Samiti (Regd.) at FC-384
Dheer Pur Ph-I Delhi used as Hostel comprised of Basement, Stilt + four
Upper floors owned/occupied by JAN KALYAN
SIKSHA SAMITI (Regd.) DELHI complied with the fire prevention and fire
safety requirement in accordance with rule 33 of the Delhi Fire Service Rule 2010 and verified
by the officer concerned of Fire Service on 26/4/12 in the presence of
Care Taker and that the building/premises is fit for occupancy
As Hostel (Residential) building with effect from 07/05/12 for a period of
03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 07/05/12 at New Delhi.



Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Authorised Signatory
Sankalp Bhawan
P.No-15, Sect-4, R.K. Puram N. Delhi

2. The Joint Director (C & I Bldg.)
Delhi Development Auth.
Bldg. Section Vikas Sadan
INA Mkt. N. Delhi.

Note:-Guidelines overleaf may also be taken care of.

20
Red
7.5.12

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : SAMKAL P. Plot No - FC-3 & 4, Dheerpar, Phase I, Delhi.
2. Type of Occupancy : Hostel (Residential)
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : Recommendation for Fire fighting as per NBC part-IV issued vide letter no. F6/DFS/MS/2069/294 dt- 2/2/09
6. Date of inspection : 5/9/11
7. Name of the Inspecting Officers : VIPIN KENTAL
8. Name and designation of officers from the building side : SH. ASHOK GUPTA.
9. Year of Construction : 2008.
10. Applicant's letter No. : nil dated 27.07.11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width		more than 6mtr	M/R
	• Gate width		6mtr (gate not provided)	M/R
	• Width of internal road		no internal road.	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors		Two no	M/R
	• Basements		Two no + one ramp	M/R
	b. Width of staircases			
	• Upper Floors	1.25 mtr as per NBC 1983	(i) 1500 mm	M/R
	• Basements	do	Two no. - (i) 1490 mm Two stair case (i) 1530 mm one ramp - 2700 mm.	M/R
	c. Protection of exits			
	• Fire check door	Required for basement	N.P	NMR
	• Pressurization	Not required	N.P	-
	e. No. of continuous staircases to terrace		Two	
	g. Width of Corridor	1 mtr	main - 3300 mm connecting mm. corridor - 2000 mm.	M/R
	h. Door Size	1 mtr (1000 mm)	1120 mm.	M/R

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	<i>Not required</i> - do -	N.P N.P	- -
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	<i>Not required</i>		
		-	N.P	-
		-	N.P	-
		-	N.P	-
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	<i>Not required</i>		
		-	N.P	-
		-	N.P	-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	<i>Not required</i>		
		-	N.P	-
		-		-
		-		-
		-		-
		-		-
		-		-
		-		-
		-		-
		450 LPM.	900 LPM	
			5.4 mtr.	
			main supply only	NMR
			Not functional.	NMR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	<i>Not required</i> -	N.P N.P	- -

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	Required for sprinkler system	provided	M/R
		N.R		
		5000 ltr.	15000 ltr.	M/R
15	Exit Signage.	Required	N.P	N/MR
16	Provision of Lifts.	not required	not provided	-
	• Pressurization of Lift Shaft	-	left yet not provided	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17	Standby power supply	Required	provided	M/R
18	Refuge Area.	N.R		
	➤ Total Area	-	Not provided	-
	➤ Location	-		-
19	Fire Control Room	not required		
	• Detector System Panel		N.P	
	• Flow Switch Panel	/	-	/
	• PA System Panel	/	-	/
	• Batter backup	/	N.P	/
	• Building Floor Plans	/	N.P (in complete plans)	/
20	Special Fire Protection Systems for Protection of special Risks, if any:	No such risk exist	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers. 2.(C.), 3(C), 4, 5, 10, 13, 15 & 19.

Signature of the Inspecting Officer

Kental
5/9/11
Signature of the Inspecting Officer

Name

Name *VIPIN KENTAL*

Designation

Designation *DO, NW*

Ref letter no. *nil* dt *16.04.12* received from Authorized signatory of *Sri Kalyan Siksha Samiti*. The inspection of premise was carried out again by *DO, NW* & observed that the compliance of all short comings have been made by management.

Keeping in view of above the fire safety certificate is enclosed for approval & sign. b1.

Kental
27/4