

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No: *F6/DFS/MS/GH/2012/1670*

Dated: *09/05/12*

FIRE SAFETY CERTIFICATE

Certified that the **Shiva Dx. Guest House** located at 4623, Shora Kothi, Main Bazaar, Pahar Ganj, New Delhi-110055 comprised of ground floor (reception + 02 guest rooms), 1st floor (05 guest rooms), 2nd floor (05 guest rooms), 3rd floor (05 guest rooms), and 4th floor (sealed by MCD) Total 17 guest room was granted NOC by this department vide letter No. F6/DFS/MS/GH/2009/809 dated 20-03-2009. The premises was re-inspected by the officer concerned of this department on 26-04-2012 in the presence of Sh. Arun Rajput and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 17 rooms with effect from *09/05/12* for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.


Issued *09/05/12* at New Delhi by.



CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi - 110049
2. Sh. Parmod Kumar M/s **Shiva Dx. Guest House**, 4623, Shora Kothi, Main Bazaar, Pahar Ganj, New Delhi-110055



Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Shiva Ds Guest House, 4623, Shora Kothi, Main Bazaar, Patna (Gan), N.D.
2. Type of Occupancy : Residential (Guest House)
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. F6/DFS/MS/GH/2009/809 Dated: 20-03-2009
5. Fire Safety directives letter No : N/A
6. Date of inspection : 26-04-2012
7. Name of the Inspecting Officers : Sh. D.S. Yadav (A.D.O)
8. Name and designation of officers from the building side : Sh. Arun Rajput (Manager)
9. Year of Construction : N/A
10. Applicant's letter No. : 13807-08/Ada. CP/Lic. (H), dated New Delhi the 09-03-12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks
1	Access to building		<u>P.S.D. Area.</u>	<u>MR/NMR</u> Old Case
	• Road width	<u>N.A.</u>	<u>N.A.</u>	<u>NA.</u>
	• Gate width	<u>NA</u>	<u>N.A.</u>	<u>NA.</u>
	• Width of internal road	<u>N.A.</u>	<u>N.A.</u>	<u>NA.</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>01</u>	<u>01</u>	<u>MR</u>
	• Basements	<u>NA</u>	<u>N.A.</u>	<u>N.A.</u>
	b. Width of staircases			
	• Upper Floors	<u>—</u>	<u>106 to 108 cm.</u>	<u>MR.</u>
	• Basements	<u>N.A.</u>	<u>N.A.</u>	<u>N.A.</u>
	c. Protection of exits			
	• Fire check door	<u>N.A.</u>	<u>N.A.</u>	<u>N.A.</u>
	• Pressurization	<u>N.A.</u>	<u>N.A.</u>	<u>N.A.</u>
	e. No. of continuous staircases to terrace	<u>01</u>	<u>01</u>	<u>MR.</u>
	g. Width of Corridor	<u>N.A.</u>	<u>NA.</u>	<u>NA.</u>
	h. Door Size	<u>N.A.</u>	<u>N.A.</u>	<u>N.A.</u>

contd.:-

Shiva Ds Guest House, 4623, Shora Kothi,
Main Bazaar, Pahar Ganj, New Delhi

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N.A	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	- N.A - - N.A - N.A	N.A. N.A.
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	— — ISI marked	10 Water Co2, D.CP Yes	MR. MR. MR.
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30 m 5 mm	01 Yes Yes	MR MR MR.
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N.A	
8	MOEFA	Yes	Yes	MR.
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	NA	N.A	NA

contd:-

Shiva D.A. Guest House, 4623, Shooru Kothi,
Main Bazaar, Pahar Ganj, New Delhi

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA		
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA		
		450 Lpm	Yes	MR.
		30 Mtr.	Yes	MR
		Yes	Yes	MR
		Yes	Yes	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	NA	NA	NA
		NA	NA	NA

contd:-

Shiva Dc. Guest House, 4623, Shora Kothi
Main Bazaar, Patna Gauri, New Delhi - 110001

	<ul style="list-style-type: none"> > Fire service inlet > Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
15	Exit Signage.	2500 Ltrs.	2500 Ltrs.	MR.
16	Provision of Lifts.	Yes	Yes	MR.
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N.A	
17	Standby power supply	Yes	Yes (D.G. set)	MR.
18	Refuge Area.			
	<ul style="list-style-type: none"> > Total Area > Location 	NA	NA	NA
		NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		N.A	
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... contd.

Shiva Ds. Guest House, 4623, Shora Kotli, Main Bazaar,
Pahar Ganj, New Delhi.

(5)

Signature of the Inspecting Officer

Name

Designation

D.O. (central) / [Signature] / 4/5/12

Yadav
03-05-12

Signature of the Inspecting Officer

Name (Dharm vir singh yadav)

Designation Assistant Divisional
officer
(central)