

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No. *F6/DFS/MS/EH/2012/1672*

Dated : *08/05/12*

FIRE SAFETY CERTIFICATE

Certified that the Restaurant in the name and style of The Corus Restaurant at ground floor located at B-14/1-6, Connaught Palace, New Delhi comprised of ground plus three floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2009/1050 dated 21-04-2009. The premises was re-inspected by the officer concerned of this department on 25-04-2012 in the presence of Mr. Satish Kumar Sharma and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for Class D (Assembly) occupancy with effect from *..08/05/..2012* for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued *..08/05/..12* at New Delhi by.


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :-

1. M/s The Corus Restaurant, (A unit of Runwell (1) Pvt. Ltd.), B-14/1-6 Middle Corcle, Connaught Palace, New Delhi -110001
2. Medical officer of Health, Health Department, Palika Kendra, Sansad Marg, New Delhi-110001

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

- 1. Name & address of the building : The Corus Restaurant, B14/1-b, Connaught Palace, N. D.
- 2. Type of Occupancy : Restaurant - 110001
- 3. Type of Case : New Case/ Renewal
- 4. Details of previous NOC : Letter No. FG/DFS/MS/EH/2009/1050 Dated: 21-04-2009
- 5. Fire Safety directives letter No : NA
- 6. Date of inspection : 25-04-2012
- 7. Name of the Inspecting Officers : Sl. D.S. Yadav (A.D.O)
- 8. Name and designation of officers from the building side : Sl. Sg. Ish Kumar Sharma (G.M)
- 9. Year of Construction : NA
- 10. Applicant's letter No. : NIL Dated 13-03-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC <i>circular</i> Requirement	Provided at site	Remarks MR/NMR <i>Old Cost.</i>
1	Access to building			
	• Road width	—	<i>more than 6mtrs</i>	<i>M.R</i>
	• Gate width	<i>NA</i>	<i>NA</i>	<i>NA</i>
	• Width of internal road	<i>NA</i>	<i>NA</i>	<i>NA</i>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	• Basements	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	b. Width of staircases			
	• Upper Floors	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	• Basements	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	c. Protection of exits			
	• Fire check door	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	• Pressurization	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	e. No. of continuous staircases to terrace	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	g. Width of Corridor	<i>NA</i>	<i>NA</i>	<i>NA</i>
	h. Door Size	<i>NA</i>	<i>NA</i>	<i>NA</i>

Contd. -

old case

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			N.A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors (G.F) 	30 a/c per hour 12 a/c per hour	NA Exhaust Fan NA	NA M.R. NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	06 Water, Co ₂ , A.B.C Yes	MR. MR. MR.
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30 m 5 mm	01 Yes Yes	MR. MR. MR.
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			N.A
8	MOEFA	Yes	Yes	MR.
9	Public Address System.	Yes	Yes	MR.
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	NA	NA	NA

contd:-

The Corus Restaurant, B-14/11-6, Connaught Palace, New Delhi

old case

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA		
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA		
		450 Lpm	Yes	MR.
		30 Mtr.	Yes	MR.
		Yes	Yes	MR.
		Yes	Yes	MR.
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	NA	NA	NA
		NA	NA	NA

contd:-

The Corus Restaurant, B-14/1-6, Connaught Palace, New Delhi

old case

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
15	Exit Signage.	10,000 Ltrs	10,000 Ltrs.	MR.
16	Provision of Lifts.	Yes	Yes	MR.
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N.A.		
17	Standby power supply	Yes	Yes (D.G. set)	MR.
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N.A	NA	N.A
		N.A	N.A	N.A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N.A.		
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Contd:-

The Corus Restaurant, B-14/1-6, Connaught Palace, New Delhi

(5)

Signature of the Inspecting Officer

Name

Designation

~~D.O. (Central)~~

~~A/05/12~~

~~03-05-12~~

Signature of the Inspecting Officer

Name Dharmvir Singh Yadav

Designation A.D.O (Central)