

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2012 / GH / 1659

Dated 08/05/12

**FIRE SAFETY CERTIFICATE**

Certified that the VV Inn Guest House, located at 1015, Gali Mantola, Pahar Ganj, New Delhi, comprised of Ground + Three upper floor having 14 Guest rooms (Ground floor has 02 Guest rooms, 1<sup>st</sup> to 3<sup>rd</sup> floor has 04 Guest rooms at each floor) was inspected by the officers concerned of this department on 23.04.2012 in the presence of Mr. Dharam Pal and found that the said Guest House have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Residential" A-I with effect from 08/05/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 08/05/12 at New Delhi by.



Chief Fire Officer  
For Director  
Delhi Fire Service

*o/c*  
*Mu*

Copy to:-

1. Sh. Dharam Pal Vij, VV Inn, 1015, Gali Mantola, Pahar Ganj, New Delhi.
2. The Addl. Comm. of Police (Lic) First Floor, Police Station Defence Colony, New Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. This NOC is for Guest Rooms only.

**INSPECTION REPORT**

1. Name & address of the building : VV Inn, 1015, Gali Mamola, Patna
2. Type of Occupancy : Residential (Guesthouse)
3. Type of Case :  New Case/  Renewal
4. Details of previous NOC : Letter No. N/A Dated: \_\_\_\_\_
5. Fire Safety directives letter No : N/A
6. Date of inspection : 23/04/12
7. Name of the Inspecting Officers : AO D.S. Yadav & DO ATULGARJ
8. Name and designation of officers from the building side : MR Dharampal
9. Year of Construction : Before 2000
10. Applicant's letter No/Addicp : 14765-64/Addicp/Lic/H/ dated 16/2/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	N/A	3 Mts	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	2	2	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	1.25mt	1.20mt	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	2	2	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.25mt	1.30M	MR



V. V. INN at 1015, Gali Mandatai,  
Main Bazar, Paharganj

3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	• Total numbers		20	MR
	• Types		WT, CO <sub>2</sub> , ABC	MR
	• IS marking	ISI marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor		1	MR
	• Length of hose reel hose	30 m	Yes	MR
	• Nozzle diameter	5 mm	Yes	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>			
		Yes	Yes	MR
9	<b>Public Address System.</b>			
		Yes	Yes	MR
10	<b>Automatic Sprinkler System.</b>			
	• Basement	N/A	N/A	N/A

contd: -





	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	NA
		5000 L	5000 L	MR
15	<b>Exit Signage.</b>	Ys	Ys	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage			
17	<b>Standby power supply</b>	Ys	Ys	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....X.....

contd.:

VV-IN, at 10/5, Gali MANTOLA, Paharganj

(5)

  
Signature of the Inspecting Officer

Name ATUL GARG

Designation DD/CC

  
Signature of the Inspecting Officer

Name Dheeraj Singh

Designation A.D.O (constd)