

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DPS/MS/school/2012/1690

Dated: 10/05/12

FIRE SAFETY CERTIFICATE

Certified that the G.C. Public School at New Ashok Nagar, Delhi-96, comprised of ground plus two upper floors owned/occupied by G.C. Public School have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and verified by the officer concerned of Fire Service on 23.4.2012 in the presence of Sh. Kali Charan, cashier, of the school and that the building is fit for occupancy class B' Educational Building' with effect from ...10/05/12. for a period of **three** years, subject to conditions printed overleaf.

Issued on.....10/05/12.....at New Delhi by



Chief Fire Officer
Delhi Fire Service

etc
men

Principal
G.C. Public School
New Ashok Nagar, Delhi-96,

Copy to:-

The Director of Education
Govt. of NCT of Delhi
Old Secretariat, Delhi-51.

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: G.C. Public School at New Ashok Nagar, Delhi -96.
2. Building is comprised of : Ground +2, upper floor.
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : Circular Director of Education dated 1.3..11
7. Date of Inspection : 23.04.12
8. Name of the Inspecting officers: DO Virendra Singh
9. Name and designation of Officer:
from the building side : Sh.Kali Charan (cashier).
10. Year of Construction - : 1990
11. Applicant's letter No : letter No.Nil dated 17.03.2012.

NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	-----	06 Mtrs.	MR
	• Gate width	-----	-----	-----
	• Width of internal road	-----	-----	-----
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 Nos.	02 Nos. ✓	MR
	• Upper Floor	02 Nos	02 Nos. ✓	MR
	• Basement	-----	-----	-----
	B. Width of Staircases	1.2 M	1.2 m	MR
	• Upper Floor	1.2 M	1.2 m ✓	MR
	• Basement	-----	-----	-----
	c. Protection of exits	-----	-----	-----
	• Fire check door	-----	-----	-----
	• Pressurization	-----	-----	-----
	e. No. of continuous staircases to terrace	2 nos.	1No.	MR
	g. Width of Corridor	1.5 mts.	1.5 mts	MR
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR



12	Yard Hydrants.			
	• Total number of hydrants	-----	-----	-----
	• Hose Box	-----	-----	-----
13	Pumping Arrangements.			
	• Ground Level	-----	-----	-----
	➤ Discharge of main Pump	-----	-----	-----
	➤ Head of Main Pump	-----	-----	-----
	➤ Number of main pumps	-----	-----	-----
	➤ Jockey pump out put	-----	-----	-----
	➤ Jockey pump head	-----	-----	-----
	➤ Standby pump out put	-----	-----	-----
	➤ Standby pump Head	-----	-----	-----
	➤ Auto Starting /Manual stopping	-----	-----	-----
	➤ Pump House Access	-----	-----	-----
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM ✓	Provided	MR
	➤ Head of the Pump	40 LPM ✓	Provided	MR
	➤ Power supply	Required ✓	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	-----	-----	-----
	➤ Draw-off connection	-----	-----	-----
	➤ Fire service inlet	-----	-----	-----
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000, ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	-----	-----	-----
	• Firemen's grounding switch	-----	-----	-----
	• Lift Signage	-----	-----	-----
17	Standby power supply	-----	-----	-----
18	Refuge Area.			
	• Total area	-----	-----	-----
	• Location	-----	-----	-----
19	Fire Control Room			
	• Detector system panel	-----	-----	-----
	• Flow switch panel	-----	-----	-----

G.C. Public School New Ashok Nagar

@

	<ul style="list-style-type: none"> • PA system panel 	-----	-----	-----
	<ul style="list-style-type: none"> • Battery backup 	-----	-----	-----
	<ul style="list-style-type: none"> • Building Floor Plans 	-----	-----	-----
20	Special Fire Protection systems for protection of special Risks, if any:	-----	-----	-----

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Name VIRBENDRA SINGH

Designation DO