

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


NO.F6/DFS/MS/ /2012/1639

Dated: 04/05/2012

FIRE SAFETY CERTIFICATE

Certified that Delhi Secretariat Building located near I.G.Stadium, I.P.Estate, New Delhi comprised of main building (ground and nine upper floors) and parking block (Double basements) was granted NOC by this department vide letter No. F.6/DFS/MS/2001/487 dated 21-03-2001. The premises was re-inspected by the officer concerned of this department on 03-04-2012 in the presence of Mr. A.K.Vasist (A.E, Elect) & Mr. O.P.Srivastava, (J.E., Elect.) and other officials of PWD and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **Business (Office)** with effect from ~~04-05-12~~ for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on ~~04/05/12~~ at New Delhi by.


**Chief Fire Officer
For Director
Delhi fire service**

Copy to: -

1. The Principal. Secretary (GAD),
Delhi Sachivalaya Building, Govt. of NCT of Delhi, I.P.Estate, Delhi.
2. The Principal Secretary(PWD),
Delhi Sachivalaya Building, 5th floor, B-Wing, Govt. of NCT of Delhi, I.P.Estate, Delhi.
3. The Principal Secretary(Home),
Delhi Sachivalaya Building, 5th floor, C-Wing, Govt. of NCT of Delhi, I.P.Estate, Delhi.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in