

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE**

NEW DELHI-110001

No. F6/DFS/MS/H/2012/1741

Dated : 14/05/12

FIRE SAFETY CERTIFICATE

Certified that the **Vishwa Yuvak Kendra, Circular Road, Chanakyapuri, New Delhi-110021**. Comprised of **Basement Ground + 4 Upper Floor** was granted NOC vide office letter No. **F6/DFS/MS/H/2009/1103 Dated 23/04/09**. The premises was inspected by the officer concerned of this department on **24/04/12** in the presence of **Mr. B.S. Rathor** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group - A Residential Dormitory Building** with effect from 14/05/12 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 14/05/12 at New Delhi by.


Chief Fire Officer
Delhi Fire Service

Copy to:- (1) The Addl. Commissioner of Police, (Lic.),
First Floor, PS Defence Colony, New Delhi.

(2) Vishwa Yuvak Kendra,
Circular Road, Chanakyapuri, New Delhi-110021.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Vishwa Yuvak Kendra, Circular Road, Chanakyapuri, New Delhi-110021.
2. Type of occupancy:- Group – A Residential Dormitory Building
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/H/2009/1103 Dated 23/04/09
5. Fire safety directives No.-
6. Date of inspection:- 24/04/12.
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. B.S.Rathor.
9. Year of construction:- 1969.
10. Applicant's letter No:- 12102/Addl.C.P./Lic.(H) dated 28/02/12 Basement, Ground + 4 upper Floor

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | BBL Requirement | Provided at site | Old Case Remarks MR/NMR |
|-----------|---|-----------------|--------------------|-------------------------------|
| 1. | Access to Building | | | |
| | 1) Road width | 9 mtr. | 15 mtr. ✓ | MR |
| | 2) Gate width | Yes | 4.5 mtr. ✓ | MR |
| | 3) Width of internal road | N/A | N/A | N/A |
| 2. | Number, Width Type & Arrangement of Exits | | | |
| | A. Number of staircases | | | |
| | 1. Upper floors | 2 Nos. | 2 Nos. ✓ | MR |
| | 2. Basements | 2 Nos. | 2 Nos. ✓ | MR |
| | B. Width of staircase | | | |
| | 1. Upper floors | Yes 125cms | 127 & 120 cms. ✓ | MR |
| | 2. Basements | Yes 125cm | 127 & 150 cms. ✓ | MR |
| | C. Protection of exits | | | |
| | 1. Fire check door | Yes | Provided ✓ | MR |
| | 2. Pressurization | N/A | N/A | N/A |
| | D. No. of continuous staircase to terrace | one | one ✓ | MR |
| | E. Width of corridor | N/A | N/A | N/A |
| | F. Door size | 1 mtr. | 1 mtr. ✓ | MR |
| 3. | Compartmentation | | | |
| | 1) Fire check door | N/A | N/A | N/A |
| | 2) Sealing of electrical shafts | N/A | N/A | N/A |
| | 3) Fire rating of shaft door | N/A | N/A | N/A |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | 1) Basements | 30 a/c per hour | Exhaust fan ✓ | MR |
| | 2) Upper floors | 12 a/c per hour | Natural ✓ | MR |
| 5. | Fire Extinguishers | | | |
| | 1) Total numbers | | 24 Nos. ✓ | MR |
| | 2) Types | ISI Marked | ABC, Co2 & W.Co2 ✓ | MR |

| | | | | |
|-----|---|---------------|-------------------|-----|
| | 3) ISI marking | | Yes | MR |
| 6. | First-Aid Hose Reel | | | |
| | 1) Total number of each floor | Yes | two at each floor | MR |
| | 2) Length of hose reel hose | 30 m | Yes | MR |
| | 3) Nozzle diameter | 5 mm | Yes | MR |
| 7. | Automatic Fire Detection & Alarming System | | | |
| | 1) Type of detectors | N/A | N/A | N/A |
| | 2) Location of main panel | N/A | N/A | N/A |
| | 3) Location of repeater panel | N/A | N/A | N/A |
| | 4) Alternate source of power | N/A | N/A | N/A |
| | 5) Hooter's Location | N/A | N/A | N/A |
| 8. | MOEFA | Yes | Provided | MR |
| 9. | Public Address System | Yes | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | 1) Basement | Yes | Provided | MR |
| | 2) Upper floors | N/A | N/A | N/A |
| | 3) Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | 1) Size of riser/down-comer | N/A | N/A | N/A |
| | 2) Number of hydrants per floor | N/A | N/A | N/A |
| | 3) Hose box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | 1) Total number of hydrants | N/A | N/A | N/A |
| | 2) Hose box | N/A | N/A | N/A |
| 13. | Pumping Arrangement | | | |
| | 1) Ground level | | | |
| | a) Discharge of main pump | 900 LPM | 900 LPM | MR |
| | b) Head of main pump | 40 mtr. | 40 mtr. | MR |
| | c) Number of main pump | One | One | MR |
| | d) Jockey pump out put | N/A | N/A | N/A |
| | e) Jockey pump head | N/A | N/A | N/A |
| | f) Stand by pump output | N/A | N/A | N/A |
| | g) Stand by pump head | N/A | N/A | N/A |
| | h) Auto starting/Manual stopping | N/A | N/A | N/A |
| | 2) Terrace level | | | |
| | a) Discharge of pump | 900 & 180 LPM | 900 & 180 LPM | MR |
| | b) Head of pump | 40 mtr. | 40 mtr. | MR |
| | c) Power supply | Yes | D.G. set | MR |
| | d) Auto starting of pump | Yes | Yes | MR |
| 14. | Captive Water Storage for Fire Fighting | | | |
| | 1) Under ground tank capacity | 50,000 ltrs. | 50,000 ltrs. | MR |
| | a) Draw-off connection | Yes | Provided | MR |
| | b) Fire service inlet | Yes | Provided | MR |
| | c) Access to tank | N/A | N/A | N/A |
| | d) Over head tank capacity | 10,000 ltrs. | 10,000 Ltr. | MR |
| 15. | Exit Signage. | Yes | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |

| | | | | |
|--|---------------------------------|-----|-----|-----|
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |
| | d) Fireman's switch | N/A | N/A | N/A |

| | | | | |
|-----|--|-----|----------|-----|
| | e) Lift signage | N/A | N/A | N/A |
| 17. | Stand by Power Supply | Yes | Provided | MR |
| 18. | Refuge Area | N/A | N/A | N/A |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | N/A | N/A | N/A |
| | a) Detector system panel | N/A | N/A | N/A |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | N/A | N/A | N/A |
| | d) Battery backup | N/A | N/A | N/A |
| | e) Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: | | | N/A |

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name

Name:- S.S.Kaushik.

Designation

Designation:-Assistant Divisional Officer.

[Handwritten signature]

[Handwritten signature]
7/5/12

[Handwritten signature]
7/5/12