

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110 001.


No. F6/DFS/MS/2012/motel/1797

Dated: 18/05/12

FIRE SAFETY CERTIFICATE

Certified that the **MDR HOTELS PVT. LTD** at ,Khasra no.14/4,14/5,15/1,15/2, Village Singhola, New Delhi comprised of **ground floor only** owned/occupied by **MDR HOTELS PVT. LTD.** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 11/5/12 in the presence of Sh.B.K.Sharma and that the building/premises is fit for occupancy class Assembly (Banquet Hall) with effect from..18/05/12..for a period of03. years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on18/05/12..... at New Delhi by


Chief Fire Officer
Delhi Fire Service

OC
17.5.2012

Copy to:-

1. The Executive Engineer (B) , HQ,
North Delhi Municipal Corporation,
8th Floor, Civic centre, Minto Road
2. The Director ,MDR Hotels(p) ltd.
Khasra no. 14/4,15/4,15/1,15/2
Vill.- Singhola new delhi

Note :- guidelines overleaf may be also be taken care of.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : MDR Hotels Pvt Ltd, Khajuraho rd. 14/14, 14/15, 15/1
2. Type of Occupancy : Assembly (Banquet hall) 1st fl. Vill Singhela Bldg.
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. - Dated: - -
5. Fire Safety directives letter No : FE/DFS/MORS/BE/metal/2012/16-18 dt 4-5-12
6. Date of inspection : 11.05.12
7. Name of the Inspecting Officers : DO Vipin Khandelwal
8. Name and designation of officers from the building side : Sh. B. K. Sharma
9. Year of Construction : 2011-12
10. Applicant's letter No. : nil dt 8-5-12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>P</u>	<u>M/R</u>
	• Gate width	<u>6 mtr</u>	<u>P</u>	<u>M/R</u>
	• Width of internal road	<u>N.A.</u>	<u>-</u>	<u>-</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>Two</u>	<u>Two</u>	<u>M/R</u>
	• Basements	<u>N.A.</u>	<u>-</u>	<u>-</u>
	b. Width of staircases			
	• Upper Floors	<u>1.5 mtr</u>	<u>1.53 mtr</u>	<u>M/R</u>
	• Basements	<u>1.25 mtr</u>	<u>1.46 mtr</u>	
	c. Protection of exits			
	• Fire check door	<u>N.A.</u>	<u>-</u>	<u>-</u>
	• Pressurization	<u>R</u>	<u>P</u>	<u>M/R</u>
	e. No. of continuous staircases to terrace	<u>N.A.</u>	<u>-</u>	<u>-</u>
	g. Width of Corridor	<u>-</u>	<u>-</u>	<u>-</u>
	h. Door Size	<u>2 mtr</u>	<u>openings more than 2 mtr</u>	<u>M/R</u>

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	on stair case	P	MIR
		no gate shaft	-	-
		-	-	-
		-	-	-
		-	-	-
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N.A.	-
		12 a/c per hour	P	MIR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	12 nos ABC water/CO2	P	MIR
		ISI marked		
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	1 no	P	MIR
		30 m	P	"
		5 mm	P	"
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N.A.		
8	MOEFA	R	P	MIR
9	Public Address System.	N.A.	-	-
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N.A.	-	-

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	N.A.		
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm.	P	M/R
		1 NO.	P	"
		1 NO.	P	"
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N.A.	4 NO.	-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N.A.	1620 LPM	-
			60 mtr	-
			me	-
			180 LPM	-
			60 mtr	-
			-	-
			-	-
			-	-
		900 LPM	P	M/R
		-	-	-
		R	P	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	N.A.	1,00,00,000lt	-
				-

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	no lift in premise		
17	Standby power supply			
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA		
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA		
20	Special Fire Protection Systems for Protection of special Risks, if any:			
			NO HT/LT panel room as yet	

- ✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.
- ✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ issue shortcomings as noted at serial numbers *NA*

Signature of the Inspecting Officer

Name

Designation

Ventat
Signature of the Inspecting Of

Name *VIPIN KENTAL*

Designation *DO, NAL*