

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/2012/1854

Dated: 22/05/2012

**FIRE SAFETY CERTIFICATE**

Certified that the **13 WEST RESTAURANT & BAR** located at A-13, Vishal Enclave, Rajouri Garden, Najafgarch Road, Delhi, comprised of basement, ground plus three upper floors was granted NOC by this department vide letter No. F-6/DFS/MS/EH/08/1204 dated 25/04/08. The premises was re-inspected by the officers concerned of this department on **16/05/2012** in the presence of **Manager** of the Restaurant and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class -D (Assembly)** occupancy with effect from 22/05/12 for a period of three years subject to conditions printed overleaf.

Issued on 22/05/12 at New Delhi by



Chief Fire Officer  
Delhi Fire Service



Copy to:  
Manager  
**13 WEST RESTAURANT & BAR**  
A-13, Vishal Enclave, Rajouri Garden, Najafgarch Road, Delhi

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified by the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Ram Parkash

May Kindly peruse letter no. nil dated 12-05-12 received from Authorized Signatory regarding of NOC in r/o 13 West Restaurant & Bar located at A-13, Vishal Enclave, Rajouri Garden, Najafgargh Road, Delhi. Accordingly premises was inspected & observed that the building comprised of basement, ground floor, first floor, Second floor. & third floor. Fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : **13 WEST RESTAURANT & BAR** located at A-13, Vishal Enclave, Rajouri Garden, Najafgargh Road, Delhi.
2. Type of Occupancy : Class -D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : F-6/DFS/MS/EH/08/1204 dated 25/04/08
6. Date of inspection : 16-05-2012
7. Name of the Inspecting Officers : D.O. Sunil Chawdhary & ADO S.S. Tuli
8. Name and designation of officers  
From the building side : Manager
9. Year of Construction :
10. Applicant's letter No. : Nil dated 12-05-12

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	06 mtrs	40 mtr approx.	M.R.
	• Gate width	N.R. building is abutting main road	N.R.	M.R.
	• Width of internal road	N.R.	N.R.	N.R.
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	2	2	M.R.
	• Basement	2	2	M.R.

	b. Width of staircases			
	• Upper Floors	70 cm approx.	Provided	M.R. as the case is for renewal
	• Basement	70 cm approx.	Provided	M.R. " "
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	Required	Provided	M.R.
	d. No. of continuous staircases to terrace	02	02	M.R.
	e. Width of Corridor	Halls only	Halls only	M.R.
	f. Door size	2 mtrs	2 mtrs	M.R.
3.	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	M.R.
	• Sealing of electrical shafts	N.A.	N.A.	N.A.
	• Fire Rating of shaft door	N.A.	N.A.	N.A.
	• Water Curtain	N.A.	N.A.	N.A.
	• Fire Dampers	N.A.	N.A.	N.A.
4.	<b>Smoke Management System.</b>			
	• Basements	Required	Exhaust fans provided	M.R.
	• Upper floors	Required	Natural Ventilation	M.R.
5.	<b>Fire Extinguishers</b>			
	• Total numbers	16	<i>13</i>	M.R.
	• Types	ABC & CO <sub>2</sub> type	provided	M.R.
	• ISI marking	ISI marked	provided	M.R.



<b>6.</b>	<b>First-Aid Hose Rees.</b>			
	• Total numbers on each floor	1	Provided	M.R. ✓
	• Length of hose reel hose	30 m	Provided	M.R. ✓
	• Nozzle diameter	5 mm	Provided	M.R. ✓
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N.R.	Provided	M.R. ✓
	• Location of Main Panel	Ground floor	Provided	M.R. ✓
	• Location of Repeater Panel	Each floor	Provided	M.R. ✓
	• Alternate source of power	Required	Provided	M.R. ✓
	• Hooter's Location	Required	Provided	M.R. ✓
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M.R. ✓
<b>9.</b>	<b>Public Address System.</b>	Required	Provided	M.R. ✓
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	• Basement	Required	Provided	M.R. ✓
	• Upper Floor	N.R.	Provided	M.R. ✓
	• Sprinkler above false ceiling	N.R.	Provided	M.R. ✓
<b>11.</b>	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100 mm	Provided	M.R. ✓
	• Number of hydrants per floor	1	Provided	M.R. ✓

	• Hose Box	1	Provided	M.R.
<b>12</b>	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N.R.	N.R.	N.R.
	• Hose Box	N.R.	N.R.	N.R.
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	N.R.	N.R.	N.R.
	➤ Head of Main pump	N.R.	N.R.	N.R.
	➤ Number of main pumps	N.R.	N.R.	N.R.
	➤ Jockey Pump out put	180 LPM	Provided	M/R
	➤ Jockey pump head	70 mtr	Provided	M/R
	➤ Standby pump out put	N.R.	N.R.	N.R.
	➤ Standby pump Head	N.R.	N.R.	N.R.
	➤ Auto Starting/Manual stopping	N.R.	N.R.	N.R.
	➤ Pump Hose Access	N.R.	N.R.	N.R.
	<b>Terrace level</b>			
	➤ Discharge of pump	900 LPM	Provided	M.R.
	➤ Head of the pump	70 mtr	provided	M.R.
	➤ Power supply	Required	Provided	M.R.

	➤ Auto Starting of pump	Required	Provided	M.R.
<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	N.R.	N.R.	N.R.
	➤ Draw -off connection	required	provided	M.R.
	➤ Fire service inlet	required	provided	M.R.
	➤ Access to tank	required	provided	M.R.
	➤ Overhead Tank Capacity	10,000 ltrs	provided	M.R.
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	M.R.
<b>16.</b>	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N.R.	N.P	N.R. Old case
	• Pressurization of Lift lobby	N.R	N.P	N.R. Old case
	• Communication In lift Car	required	provided	M.R.
	• Fireman's Grounding Switch	required	provided	M.R.
	• Lift Signage	required	provided	M.R.
<b>17.</b>	<b>Standby power supply</b>	Not Required.	Provided	M.R
<b>18.</b>	<b>Refuge Area</b>			
		N.R.	N.R	Not applicable
	➤ Total Area	N.R.	N.R.	Not applicable
	➤ Location	N.R.	N.R.	Not applicable
<b>19.</b>	<b>Fire Control Room</b>			
		Required	provided	M.R.
	➤ Detector System Panel	Required	provided	M.R.

	➤ Flow Switch Panel	Required	provided	M.R. ✓
	➤ PA system Panel	Required	provided	M.R. ✓
	➤ Batter backup	Required	provided	M.R. ✓
	➤ Building Floor plans	Required	provided	M.R. ✓
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

Sunil Chaudhary

Name

Designation

D. O.

Designation