

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001


NO.F.6/DFS/MS/GH/2012/ 1820.

Dated: 21/05/12

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Amrit Guest House** located at 178, S. P. Mukherjee Marg, Delhi comprised of ground floor (Commercial use), Mezzanine floor (03 staff rooms) first floor (14 guest rooms+ reception + office), second floor (12 guest rooms + 01 staff room + staff kitchen), Third floor (18 Guest rooms) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/09/1073 dated 22-04-2009. The premises was re-inspected by the officer concerned of this department on 02-05-2012 in the presence of Mr. Sumit, Manager of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **residential (guest house)** for 28 rooms with effect from ~~21/05/12~~ for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on ~~21/05/12~~ at New Delhi by.



**Chief Fire Officer  
Director  
Delhi fire service**



Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1<sup>st</sup> floor, New Delhi
2. The Owner, M/s **Amrit Guest House**, 178, S. P. Mukherjee Marg, Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building : Amrit Guest House, 855, SPM Marg, Delhi.
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. FG/DFs/ru/CH/2005/1073 Dated: 22/4/2005
5. Fire Safety directives letter No : -
6. Date of inspection : 2/5/2012
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(HQ)
8. Name and designation of officers from the building side : Mr Sumit, Manager
9. Year of Construction : 1920
10. Applicant's letter No. : 8294/Addl.C.P/LRCH Dated 10/2/2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	-	6mt	MR
	• Gate width	-	Directly accessible from the road	MR
	• Width of internal road	-	-	-
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	-	01 NO.	MR
	• Basements	-	-	-
	b. Width of staircases	-	-	-
	• Upper Floors	-	1.05mt	MR
	• Basements	-	-	-
	c. Protection of exits			
	• Fire check door	Not required	-	-
	• Pressurization	Not applicable	-	-
	e. No. of continuous staircases to terrace	-	01	MR
	g. Width of Corridor	-	1.25mt	MR
	h. Door Size	-	0.91mt	MR
		-	-	-
3	<b>Compartmentation.</b>	Not required	-	-

CF - Commercial, Men's 03 Staff rooms,  
 FF - 14 Guest rooms + reception + Office.  
 SF - 12 G. rooms + 01 Staff room + Staff kitchen  
 TF - 18 G. rooms.





Amrit Guest House, 855, SPM Marg,  
Delhi

	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			
4	<b>Smoke Management System.</b>	Not required		
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour		
		12 a/c per hour		
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	Water CO <sub>2</sub> -4 CO <sub>2</sub> -4 ISI marked	provided provided provided	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	01 30 m 5 mm	provided provided provided	MR MR MR
7	<b>Automatic fire detection and alarming system.</b>	Not required		
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			
8	<b>MOEFA</b>	Not required	←	←
9	<b>Public Address System.</b>	Required	provided	MR
10	<b>Automatic Sprinkler System.</b>	Not required		
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			
11	<b>Internal Hydrants</b>	Not required		
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	←	←	←

g

	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>			
12	<b>Yard Hydrants. Not required</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>			
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level                             <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level                             <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
		225 LPM	225 LPM	MR
		-	30mt	MR
		Required	provided 15kva	MR
		-	Switch provided at first floor	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>			
		2500 Lts.	3000 Lts.	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts. Not applicable</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> </ul>	-	-	-

	<ul style="list-style-type: none"> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			
17	Standby power supply	Required	15 kVA	MR
18	Refuge Area.	Not applicable		
	➤ Total Area			
	➤ Location			
19	Fire Control Room	Not required		
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One ABC type fire ext. 5kg cap. provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer  
Name  
Designation

Signature of the Inspecting Officer  
Name (M.K. CHATTOPADHYAY)  
Designation :- Assistant Divisional Officer

D/O (Central) 13/5/12

