

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. *FG/DFS/MS/School/2012/1821*

Dated: *21/05/12*

FIRE SAFETY CERTIFICATE

Certified that the M .C.Primary School at M-Block,Nand Nagri,Delhi-93.Comprised of ground floor only owned/occupied by M .C.Primary School have complied with the fire prevention and fire safety requirements in accordance with with the circular issued by the Director of Education dtd.01.03.2011and verified by the officer concerned of Fire Service on 10.05.2012 in the presence of Principal, of the school and that the building is fit for occupancy class B' Educational Building with effect from.....for a period of **three** years ,subject to conditions printed overleaf.

Issued on *21/05/12* at New Delhi by



Chief Fire Officer
Delhi Fire Service

OC
21/5/12

To,

Principal
M .C.Primary School,1st Shift,
M-Block,Nand Nagri,Delhi-93

Copy:-

1. The Director of Education
MCD,Nigam Bhawan,
Kashmiri Gate,Delhi.
2. Principal
M .C.Primary School,2nd Shift,
M-Block,Nand Nagri,Delhi-93

:

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on

INSPECTION REPORT

1. Name & address of the building: M.C. Primary School, D-2 Block, Nand Nagri, Delhi-110033
2. Type of Occupancy : Educational
3. Type of Case : New Case / Renewal
4. Details of Previous NOC : Letter No- NIL
5. Fire Safety direction letter No : FIG/Estate/PS/CC/211/32-98 to 3398 dtd 1.3.12
6. Date of Inspection : 10.5.12
7. Name of the Inspecting officers: Dr. Virender Singh
8. Name of the designation of Officer : Smt. Usha Chauhan (Principal)
- From the building side _____
9. Year of Construction : 1976
10. Applicant's letter No: 24.04.12
11. Building is comprised of : Ground floor only

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<p style="text-align: center;">6 M</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">7 M</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">M R</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p>
2	Number, Width, Type and Arrangement of Exits	<u>NA</u>		
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 			
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 			
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			

	h. Door Size	NA		
3	Compartmentation.	NA		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 			
4	Smoke Management System.	NA		
	<ul style="list-style-type: none"> • Basement • Upper floor 	30a/c per hour 12 a/c per hour		
5.	Fire Extinguisher	NA		
	<ul style="list-style-type: none"> • Total numbers • types • IS marking 	4 Nos. ABC & CO ₂ ISI marked	Provided - -	MR MR MR
6	First-aid-Hose Reels.	NA		
	<ul style="list-style-type: none"> • Total numbers of each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm		
7	Automatic fire detection and alarming system.	NA		
	<ul style="list-style-type: none"> • Type of detectors • Location of main panel • Location of repeater panel • Alternate source of power • Hooters's location 			
8	MOEFA	N.A		
9	Public address System.	NA		
10	Automatic Sprinkler System.	NA		
	<ul style="list-style-type: none"> • basement • upper floor • sprinkler above false ceiling 			
11	Internal Hydrants	N.A		
	<ul style="list-style-type: none"> • size of riser/down-comer • Number of hydrants per floor • Hose Box 			

12	Yard Hydrants.	N.A		
	• Total number of hydrants			
	• Hose Box			
13	Pumping Arrangements.	N.A		
	• Ground Level			
	➤ Discharge of main Pump			
	➤ Head of Main Pump			
	➤ Number of main pumps			
	➤ Jockey pump out put			
	➤ Jockey pump head			
	➤ Standby pump out put			
	➤ Standby pump Head			
	➤ Auto Starting /Manual stopping			
	➤ Pump House Access			
	• Terrace Level			
	➤ Discharge of pump			
	➤ Head of the Pump			
	➤ Power supply			
	➤ Auto Starting of pump			
14	Captive Water Storage for Fire Fighting.	N.A		
	• Underground tank capacity			
	➤ Draw-off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead Tank capacity			
15	Exit Signage.	N.A		
16	Provision of Lifts.	N.A		
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication in lift car			
	• Firemen's grounding switch			
	• Lift Signage			
17	Standby power supply	N.A		
18	Refuge Area.	N.A		
	• Total area			
	• Location			

19	Fire Control Room	N.A		
	• Detector system panel			
	• Flow switch panel			
	• PA system panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection systems for protection of special Risks, if any:	N.A		

The fire extinguishers provided in the building were test /checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Name

VIRENDRA SINGH

Designation

DD (E)

Dy CFO