

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/EH/2012/1838

Dated: 21/05/12

**FIRE SAFETY CERTIFICATE**

Certified that the Mc Donald Family Restaurant at Shop No. 7 to 9, Aggarwal Fun City Mall, Plot No. 29 & 31, East CBD, Shahdara, Delhi-32 by M/S Connaught Plaza Restaurants Pvt. Ltd, comprised of ground floor was granted NOC by this department vide letter No.F.6/DFS/MS/EH/08/2401 dated 21.10.08. The premises was re-inspected by the officer concerned of this department on 26.04.12 in the presence of Mr. Anil Verma, (Asst. Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy Group -D (Assembly building) with effect from 21/05/12. Renewed for a period of three years, subject to conditions printed overleaf.

Issued on.....21/05/12.....at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

gc  
21/5  
1838/12

To

Mr. Harish Sharma,  
Connaught Plaza Restaurants Pvt. Ltd.  
13-A, Jor Bagh Market, New Delhi-3

Copy to:-

Dy. Health Officer  
M.C.D, Shahdara, South Zone, Delhi

## CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name & address of the building : Mc Donald Family Restaurant at Shop No. 7 to 9, Aggarwal Fun City Mall, Plot No. 29 & 31, East CBD, Shahdara, Delhi-32.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of Previous NOC : Letter No- F.6/ DFS/MS/EH/08/2401 Dated 21.10.08
5. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010.
6. Date of Inspection : 26.04.12
7. Name of the Inspecting Officers: : Suresh singh (ADO)
8. Name of the designation of Officer from the building side : Mr. Anil Verma (Asst. Manager)
9. Year of Construction : 2008
10. Applicant's letter No : CPRPL/FM/NOC/2011-12/20 dated 16.04.12

S.No	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	.....	30 m	MR
	Gate width	.....	6 m	MR
	Width of internal road	.....	.....	.....
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	.....	.....	.....
	Upper Floor	.....	.....	.....
	Basement	.....	.....	.....
	B. Width of Staircases	.....	.....	.....
	Upper Floor	.....	.....	.....
	Basement	.....	.....	.....
	c. Protection of exits	.....	.....	.....
	Fire check door	.....	.....	.....
	Pressurization	.....	.....	.....
	e. No. of continuous staircases to terrace	.....	.....	.....
	g. Width of Corridor	.....	.....	.....
	h. Door Size	.....	.....	.....
		2 m	2 no. 2 & 1.5 m	MR
	3	Compartmentation.	Required	Provided
	• Fire check door	.....	.....	.....
	• Sealing of electrical shafts	.....	.....	.....
	• Fire rating of shaft door	.....	.....	.....
	• Water curtain	.....	.....	.....
	• Fire Dampers	.....	.....	.....
4	Smoke Management System.	N/A		
	• Basement	30a/c per hour	.....	.....
	• Upper floor	12 a/c per hour	.....	.....

5.	Fire Extinguisher	Required		
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	2 no.	3 no.	MR
		Co2 & ABC	Co2 & ABC	MR
		ISI marked	ISI marked	MR
6	First-aid-Hose Reels.	Required		
	Total numbers of each floor	01 no.	01 no.	MR
	Length of hose reel hose	30 m	provided	MR
	Nozzle diameter	5 mm	provided	MR
7	Automatic fire detection and alarming system.	Required		
	Type of detectors	Heat & Smoke	Provided	MR
	Location of main panel	.....	.....	.....
	Location of repeater panel	.....	.....	.....
	Alternate source of power	.....	.....	.....
	Hooters's location	.....	Out side	.....
8	MOEFA	.....	Provided	MR.
9	Public address System.	.....	.....	.....
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	.....	.....	.....
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants per floor	one	one	MR
	Hose Box	one	one	MR
12	Yard Hydrants.			
	Total number of hydrants	.....	.....	.....
	Hose Box	.....	.....	.....
13	Pumping Arrangements.	Required		
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	.....	.....	.....
	➤ Discharge of main Pump	2850 LPM	2850 LPM	MR
	➤ Head of Main Pump	60 m	60 m	MR
	➤ Number of main pumps	.....	.....	.....
	➤ Jockey pump out put	.....	.....	.....
	➤ Jockey pump head	.....	.....	.....
	➤ Standby pump out put	.....	.....	.....
	➤ Standby pump Head	.....	.....	.....
	➤ Auto Starting /Manual stopping	.....	.....	.....
	➤ Pump House Access	.....	.....	.....
	<ul style="list-style-type: none"> <li>Terrace Level</li> </ul>	.....	.....	.....
	➤ Discharge of pump	.....	.....	.....
	➤ Head of the Pump	.....	.....	.....
		.....	.....	.....

{ Mc Donald Fun City Mall CBD }

6

	➤ Power supply	.....	.....	.....
	➤ Auto Starting of pump	.....	.....	.....
14	Captive Water Storage for Fire Fighting.	Required		
	Underground tank capacity	.....	1,00,000	MR
	Draw-off connection	.....	.....	.....
	Fire service inlet	.....	.....	.....
	Access to tank	.....	.....	.....
	Overhead Tank capacity	.....	.....	.....
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Yes		
	Pressurization of Lift Shaft	.....	.....	.....
	Pressurization of Lift lobby	.....	.....	.....
	Communication in lift car	.....	.....	.....
	Firemen's grounding switch	.....	.....	.....
	Lift Signage	.....	.....	.....
17	Standby power supply	.....	Yes	.....
18	Refuge Area.	N/A		
	Total area	.....	.....	.....
	Location	.....	.....	.....
19	Fire Control Room	Provided in Basement		
	Detector system panel	.....	.....	.....
	Flow switch panel	.....	.....	.....
	PA system panel	.....	.....	.....
	Batter backup	.....	.....	.....
	Building Floor Plans	.....	.....	.....
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	.....	.....

The fire protection systems provided in the building were test checked at the time of inspection and found functional.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

DO (Est)

Submitted for approval please

Dy CFO

*[Signature]*

*[Signature]*  
01/07/12

*[Signature]*

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO