

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

NO. F-6/DFS/MS/club/2012/1817

DATED: 21/05/12

**FIRE SAFETY CERTIFICATE**

Certified that the Riverside Sports & Recreation Club at Club Avenue, Mayur Vihar-1 Extn., Delhi-91, owned/occupied by Riverside Sports & Recreation Club, comprising of basement, ground plus two upper floors was granted NOC vide letter no. No.F.6/DFS/MS/2011/ 352 dated 21.02.2011. The Riverside Sports & Recreation Club building was inspected by the officer concerned of this department on 28.04.12 in the presence of Sh.R.K.Joshi, Manager of club and found that the club building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D " Club Building" with effect from ...21/05/12... for a period of three years, subject to conditions printed overleaf.

Issued on ...21/05/12... at New Delhi by



Chief Fire Officer  
Delhi Fire Service

OC  
21/5/12

Asstt. Commissioner (Club),  
GNCT of Delhi, L&N Block,  
Vikas Bhawan, I.P. Estate,  
New Delhi-110002.

Copy to:-

Manager  
Riverside Sports & Recreation Club  
Club Avenue, Mayur Vihar-1 Extn.,  
Delhi-91,

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name & address of the building : Riverside Sports & Recreation Club at Club Avenue, Mayur Vihar-1 Extn., Delhi-91.
2. Type of Occupancy : Assembly (Club Building)
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/2011/352 dated 21.02.11
5. Fire Safety directives No : F.6/DFS/MS/BP/97/481 dated 1/05/97
6. Date of Inspection : 28.04.12
7. Name of the Inspecting Officer : DO Virendra Singh
8. Name of the designation of Officer  
From the building side : Sh.R.K.Joshi(Manager)
9. Year of Construction : 1999
10. Applicant's letter No : 26/04/2012 & also Asstt. Commissioner (club) letter dtd.10/04/12

	Minimum Standards on fire prevention and fire safety U/R33	Old building Requirement	Provided at Site	Remarks
1	Access to building	12 Mtrs	30 Mtrs.	MR
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	4.5 Mtrs.	6 Mtrs.	MR
		-----	-----	-----
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 Nos.	02 Nos.	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	02 Nos	02 Nos.	MR
	B. Width of Staircases	01 No.	01 No +Ramp	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	-----	-----	-----
	c. Protection of exits	1.25 M	1.4 M + 80 CM	MR
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	1.25 M	1.4 M + 80 CM	MR
	e. No. of continuous staircases to terrace	Required	Provided	MR
	g. Width of Corridor	-----	-----	-----
	h. Door Size	1 No.	1 No.	MR
		1.5 Mtrs	1.5 Mtrs	MR
		2.0 Mtr. & 1.0 M	Provided	MR
3	Compartmentation.	Required	Provided	
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>	Required	Provided	MR
		.....	.....	.....
		.....	.....	.....
		.....	.....	.....
		.....	.....	.....
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>	.....	.....	.....
		.....	.....	.....
5.	Fire Extinguisher			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• types</li> <li>• IS marking</li> </ul>	15 nos.	26 Nos.	MR
		ABC & Co2	ABC & Co2	MR
		ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers of each floor</li> </ul>	1 no.	Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	.....	.....	.....
	<ul style="list-style-type: none"> <li>Location of main panel</li> </ul>	.....	.....	.....
	<ul style="list-style-type: none"> <li>Location of repeater panel</li> </ul>	.....	.....	.....
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Rquired	Provided	MR
	<ul style="list-style-type: none"> <li>Hooters's location</li> </ul>	.....	.....	.....
8	MOEFA	Required	provided	MR
9	Public address System.	Required	provided	MR
10	Automatic Sprinkler System.	Required	Provided	MR
	<ul style="list-style-type: none"> <li>basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>upper floor</li> </ul>	Not Required	Provided	MR
	<ul style="list-style-type: none"> <li>sprinkler above false ceiling</li> </ul>	.....	.....	.....
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>size of riser/down-comer</li> </ul>	100 mm	100 mm	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	01 no.	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	01 no.	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	.....	.....	.....
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	.....	.....	.....
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	.....	.....	.....
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	.....	.....	.....
	<ul style="list-style-type: none"> <li>➤ Head of Main Pump</li> </ul>	.....	.....	.....
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	.....	.....	.....
	<ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>	.....	.....	.....
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	.....	.....	.....
	<ul style="list-style-type: none"> <li>➤ Standby pump out put</li> </ul>	.....	.....	.....
	<ul style="list-style-type: none"> <li>➤ Standby pump Head</li> </ul>	.....	.....	.....
	<ul style="list-style-type: none"> <li>➤ Auto Starting /Manual stopping</li> </ul>	.....	.....	.....
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	900 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of the Pump</li> </ul>	60 Mtrs	60 Mtrs.	MR
	<ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>	Auto	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	50,000 Ltrs.	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	Required	Provided	MR

	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	12,500 Ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	-----	-----	-----
	• Total area	-----	-----	-----
	• Location	-----	-----	-----
19	Fire Control Room			
	• Detector system panel	-----	-----	-----
	• Flow switch panel	-----	-----	-----
	• PA system panel	-----	-----	-----
	• Batter backup	-----	-----	-----
	• Building Floor Plans			
20	Special Fire Protection systems for protection of special Risks, if any:	-----	-----	-----

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Name

Designation

*Virendra Singh*  
VIRENDRA SINGH  
DO(E)