

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/VG/2012/1861

Dated: 23/05/2012

FIRE SAFETY CERTIFICATE

Certified that **Video Game Parlour No 489/Addl, CP/Lic./(Amst)** Situated at **SF-10, 2nd floor Pacific Mall, Tagore Garden, New Delhi** was inspected by the officers concerned of this department on **20/04/2012** in the presence of **Mr. Pawan Kumar** representative of the management and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service 2010 and the premises is fit for **Video game parlour** occupancy with effect from 23 / 05 /2012 for a period of three years subject to conditions printed below.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 6) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on **www.dfs. delhigovt. nic.in**

Issued on.....23/05/12.....at New Delhi by



Director
Delhi Fire Service

Copy to.

1. Mr. Pawan Kumar S/o Sh. Raj Kumar
R/o B-84, First floor, Paryavaran Complex, Near IGNOU Road, New Delhi
2. The Addl. Commissioner of Police (Lic), 1st floor, Police Station, Defence Colony, New Delhi
w. r. t., L No 62649-53/Addl./C.P.Lic(Amst.) dated 21/12/2011,

INSPECTION REPORT

1. Name & address of the building : 2nd floor Pacific mall, T. Garden.
2. Type of Occupancy : Assembly
3. Type of Case : New Case / ~~Renewal~~
4. Details of previous NOC : Letter No. Dated:
5. Fire Safety directives letter No :
6. Date of inspection : 20/4/12
7. Name of the Inspecting Officers : DO MN & ADO(MN)
8. Name and designation of officers from the building side : Sh Pqwsqum Luma
9. Year of Construction :
10. Applicant's letter No. : 62649-53/Add CP/lic (Aunt) dtd 21/12/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Required</u>	<u>Provided</u>	<u>m/r</u>
	• Gate width	<u>1.5 m</u>	<u>Provided</u>	<u>m/r</u>
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>Two</u>	<u>Provided as per mall</u>	<u>m/r</u>
	• Basements			

b. Width of staircases				
	• Upper Floors	Regd by the m/c	Provided	m/a
	• Basements	- " -	- " -	- " -
	c. Protection of exits			
	• Fire check door	- " -	- " -	- " -
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
h. Door Size	1.5 m	- " -	m/a as per m/c n/c	
3	Compartmentation.	N/A	N/A	N/A
• Fire check door				
• Sealing of electrical shafts				
• Fire Rating of shaft door				
• Water Curtain				
• Fire Dampers				

Smoke Management System.

- Basements
- Upper floors

30 a/c per hour
12 a/c per hour

N/A
N/A
"
"

5 Fire Extinguishers

- Total numbers
- Types
- IS marking

6
ISI marked
Required

10 Nos
m/r
ABC
m/r
yes
m/r

6 First-Aid Hose Reels.

- Total numbers on each floor
- Length of hose reel hose
- Nozzle diameter

—
30 m
5 mm

Provided
m/r as per mall
— " —
— " —
— " —

7 Automatic fire detection and alarming system.

- Type of detectors
- Location of Main Panel
- Location of Repeater Panel
- Alternate source of power
- Hooters' Location

Reqd
Provided
m/r
—
—
—
—
—
—
—

8 MOEFA

Reqd
Provided
m/r

9 Public Address System.

N.R.
N.R.
N.R.

10	Automatic Sprinkler System.			
	• Basement	Reqd	Provided	m/r
	• Upper Floor	NR	N.P)
	• Sprinkler above false ceiling	Requested	Provided)
11	Internal Hydrants			
	• Size of riser/down-comer	Reqd 150 mm.	Provided as Per mall	m/r
	• Number of hydrants per floor	one.	provided)
	• Hose Box	1))
12	Yard Hydrants.			
		N/A	N/A	N/A
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	Reqd	Provided	m/r
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—

➤ Auto Starting/ Manual stopping	-	-	-
➤ Pump House Access	-	-	-
Terrace level	Reqd	Provided	n/a
➤ Discharge of pump	-	Provided as per reqd 2280 LPM	n/a
➤ Head of the pump	-	-	-
➤ Power Supply	-	-	-
➤ Auto Starting of pump	-	-	-

14 **Captive Water Storage for fire fighting.**

• Underground tank capacity	Reqd	Provided	n/a
➤ Draw-off connection	-	-	-
➤ Fire service inlet	-	-	-
➤ Access to tank	-	-	-
• Overhead Tank capacity	-	-	-

15	Exit Signage.	Reqd	Provided	N/A
16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17	Standby power supply	Reqd	Provided	N/A
18	Refuge Area.	N/A	N/A	N/A
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19	Fire Control Room	N/A	N/A	N/A
	• Detector System Panel	-	-	-
	• Flow Switch Panel	-	-	-
	• PA System Panel	-	-	-
	• Batter backup	-	-	-
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

20(m/s) dm

Signature of the Inspecting Officer

Name

Designation

Gugh
26/4/12
SSTeli
ADD (MVA)

It. Put up fire safety,
certificate

~~ADD (MVA)~~

FSC is put up please.

Gugh
27/4/12