

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2011/ *school/1898*

Dated:- *24/05/12*

FIRE SAFETY CERTIFICATE

Certified that the *Arvind Gupta DAV Centenary Public School Near Nainitalake Model Town* located at *Model Town Delhi* comprised of *Ground + 3 upper floors* occupied by *A.S. DAV Centenary Pub. School* was issued NOC vide this office letter No. *F-6/DFS/MS/2006/1898* Dated: *24/5/2006* The premises was re-inspected by the officer concerned of this department on *19/4/12* and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under Rule 33 of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class *Educational* with effect from *24/05/12* for a period of *03 years* in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *24/05/12* at New Delhi.



Chief Fire Officer
Delhi Fire Service

ok

Copy to:-

1. *The Principal*
Arvind Gupta DAV Centenary
Pub. School Near Nainitalake
Model Town Delhi
2. *The Adl. Director Edu. (ACT)*
Govt. of NCT of Delhi
Adl. Sectt.
Delhi

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Axayini Gupta D.A.V. Centenary Public School,
near Vidya Lake, Model Town, Delhi.
2. Type of Occupancy : School (Education - N/A)
3. Type of Case : New Case/ Renewal [old block for renewal -
new block as new case]
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : _____
6. Date of inspection : 19.4.12
7. Name of the Inspecting Officers : DO nipin kental
8. Name and designation of officers
from the building side : Mr. K.L. Chaudhary
9. Year of Construction : 2006
10. Applicant's letter No. : 19412 dt 12.2.12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9m	> 9m	M/R
	• Gate width	5m	P	M/R
	• Width of internal road	6m	P on right side	M/R
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2 in each block	P	M/R
	• Basements	N.A	-	-
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m - 2 No. 1.41m - 2 No.	Two stair case
	• Basements	N.A	-	-
	c. Protection of exits			
	• Fire check door	N.A	-	-
	• Pressurization	-do-	-	-
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	1.50m	P	M/R
	h. Door Size	1.00m x 2 doors for class rooms with more than 45 students	one door of 110cm class rooms have students less than 45 students	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N.A.	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N.A.	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	18 no. ISI marked	P ABC type 5 kg each	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	2 30 m 5 mm	P P P	M/R M/R M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N.A.	
8	MOEFA	R	P	M/R
9	Public Address System.	N.A.	-	-
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	NO basement		

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 		/	
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100mm	P	M/R
		2	P	M/R
		2	P	M/R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	n/a	/	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		n/a	
		450 LPM	450 LPM + 150 LPM	M/R
		40 mtr	P	M/R
		R	P	M/R
		-	-	-
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	1,50,000lt	P	M/R
		-	-	outside in court yard.

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.	R	P	MIR
		5,000 ltrs.	5000 ltrs.	MIR
16	Provision of Lifts.	R	P	MIR
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A		
17	Standby power supply	R	P	MIR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A		
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A		
20	Special Fire Protection Systems for Protection of special Risks, if any:		NO special risk at present	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers... 2, 4, 14.....

Signature of the Inspecting Officer

Name

Designation

Veerant
Signature of the Inspecting Officer

Name *VIPIN KENTAL*

Designation *DO, N.W.*